



LIST OF MATERIALS:

- ① BACKFLOW PREVENTER (SEE NOTE 1)
PROVIDE SUPPORT FOR VALVES AS NECESSARY, ELEVATE BACKFLOW PREVENTER VALVES (SEE NOTE 2).
- ② UTILITY BOX TOP SECTION & BASE c/w 6mm THICK CHECKER PLATE ALUMINUM COVER WITH 50mm RIGID INSULATION..

NOTES:

1. INSTALLATION SHOWN IS FOR A 19mm DOUBLE CHECK BACKFLOW PREVENTER. DIMENSIONS & CLEARANCES MAY VARY WITH DIFFERENT MANUFACTURERS. INSTALLATION CLEARANCES MUST BE IN ACCORDANCE WITH THE MANUFACTURERS RECOMMENDATIONS.
2. BOX MUST BE INSTALLED SUCH THAT ALL DRAIN VALVES ARE LOCATED A MINIMUM OF 50mm ABOVE MAXIMUM WATER TABLE.
3. INSTALLATION MUST BE APPROVED BY LOCAL PLUMBING INSPECTOR.
4. ALL MATERIALS TO BE IN ACCORDANCE WITH CURRENT B.C. PLUMBING CODES.
5. UTILITY BOX SHOWN FOR BACKFLOW PREVENTER IS A BROOKS PRODUCTS BCT 66E.



**DOUBLE CHECK
BACKFLOW PREVENTER
(50mm & LESS)**

revision date: APRIL 2007	scale: N.T.S.
drawn: D.R.	checked: C. GOTTFRED
standard drawing no.:	
2.2	