



LIST OF MATERIALS:

- ① 910mm x 710mm x 100mm MIN. CONCRETE SLAB.
- ② REDUCED PRESSURE BACKFLOW PREVENTER (SEE NOTE 1). PROVIDE SUPPORT FOR VALVES AS NECESSARY, ELEVATE VALVES (SEE NOTE 2).
- ③ 610mm MIN. x 610mm x 406mm x 3mm THICK CHECKER PLATE ALUMINUM ENCLOSURE WITH 50mm RIGID INSULATION INSIDE.

NOTES:

1. INSTALLATION IS FOR A 19mm FEBCO MODEL 825Y REDUCED PRESSURE BACKFLOW PREVENTER. DIMENSIONS & CLEARANCES MAY VARY WITH DIFFERENT MANUFACTURERS. INSTALLATION CLEARANCES MUST BE IN ACCORDANCE WITH THE MANUFACTURERS RECOMMENDATIONS.
2. INSTALLATION MUST BE APPROVED BY LOCAL PLUMBING INSPECTOR.
3. ALL MATERIALS TO BE IN ACCORDANCE WITH CURRENT B.C. PLUMBING CODES.



Making a difference...together

19mm REDUCED PRESSURE BACKFLOW PREVENTER ABOVE GROUND

revision date: APRIL 2007	scale: N.T.S.
drawn: PJ/DR	checked: C. GOTTFRED

standard drawing no.:

2.1