

TABLE 1. 2008 UNTREATED (RAW) WATER QUALITY AT JAPAN GULCH PLANT

(Guideline values provide reference only for untreated water)

PARAMETER		2008 ANALYTICAL RESULTS				2008 CANADIAN GUIDELINES	TEN YEAR RESULTS (1999-2008)			Target
Parameter	Units of	Median	Samples	Range		≤ = Less than or equal to	Ten Year	Samples	Range	Sampling
Name	Measure	Value	Analyzed	Minimum	Maximum		Median	Analyzed	Minimum-Maximum	Frequency
mg/L = parts per million ug/L = parts per billion ng/L = parts per trillion										
Physical Parameters (< means less than instrument can detect)										
Alkalinity, Total	mg/L	13.0	11	12.5	14.3		14.6	273	7.8 - 17.6	12/yr
Carbon, Dissolved Organic	mg/L as C	2.4	11	2.1	2.7		2.4	90	1.8 - 7.0	10/yr
Carbon, Total Organic	mg/L as C	2.4	11	2.2	2.9	Guideline Archived	2.5	148	1.8 - 9.6	10/yr
Colour, True	TCU	6.6	51	4.6	8.5	≤15 AO	7.7	566	2.8 - 18	52/yr
Conductivity @ 25 C	uS/cm	40.6	50	38.3	43.4		41.7	517	26.2 - 47.0	52/yr
Hardness as CaCO ₃	mg/L	16.1	15	12.6	19.4	No Guideline Required	16.8	161	9.3 - 34.7	12/yr
pH	pH units	7.24	51	6.79	7.66	6.5 - 8.5 AO	7.27	520	6.46 - 7.67	52/yr
Tannins and Lignins	mg/L	0.30	2	0.24	0.35	Guideline Archived	0.26	30	<0.07 - 0.37	2/yr
Total Dissolved Solids	mg/L	26.0	15	23.9	32.7	≤500 AO	25.2	237	13.0 - 49.0	12/yr
Total Suspended Solids	mg/L	0.7	15	<0.1	4.7		0.8	236	<0.1 - 7.7	12/yr
Total Solids	mg/L	27.0	15	25.0	33.0		26	236	14 - 50	12/yr
Turbidity, Grab Samples	NTU	0.39	247	0.26	0.93		0.37	2,449	0.12 - 2.8	250/yr
Ultraviolet Absorption, 5cm	Abs. @254 nm	0.288	49	0.23	0.329		0.319	450	0.206 - 0.575	52/yr
Ultraviolet Transmittance	%	87.6	244	84.9	91.0		86	1,723	75 - 94.4	250/yr
Water Temp., Grab Samples	degrees C	10.0	254	4.0	17.8	≤15 AO	10	2,695	3.0 - 22.0	250/yr
Non-Metallic Inorganic Chemicals (< means less than instrument can detect)										
Ammonia, Total	ug/L as N	5.45	11	2.56	14.2	Guideline Under Review	4.6	118	<0.18 - 63.6	12/yr
Bromide	mg/L as Br	0.006	11	0.004	0.015		0.004	75	<0.0008 - 0.021	12/yr
Bromate	ug/L	<0.09	2	<0.03	<0.15	10 MAC	<0.03	5	<0.03 - <0.6	2/yr
Chloride	mg/L as Cl	2.9	2	2.8	2.9	≤ 250 AO	2.58	20	1.82 - 6.37	2/yr
Cyanide	mg/L as Cn	<0.015	2	<0.015		0.2 MAC	<0.015	21	<0.002 - <0.015	2/yr
Fluoride	mg/L as F	<0.007	2			1.5 MAC	<0.008	20	<0.002 - 0.042	2/yr
Nitrate, Dissolved	ug/L as N	24.5	11	5.4	38		16.5	106	<0.3 - 97.8	12/yr
Nitrite, Dissolved	ug/L as N	<0.3	11				<0.3	104	<0.16 - 6.85	12/yr
Nitrogen, Total	ug/L as N	83.1	11	63.3	118		91.8	91	17 - 304	12/yr
Phosphate, Ortho, Dissolved	ug/L as P	0.79	11	<0.11	2.4		0.90	104	<0.09 - 4.41	12/yr
Phosphate, Total, Dissolved	ug/L as P	2.68	11	1.44	4.81		2.8	104	<0.4 - 7.8	12/yr
Phosphate, Total	ug/L as P	4.92	11	3.71	8.2		4.92	105	<0.7 - 13.1	12/yr
Silica	mg/L as SiO ₂	3.68	11	2.82	4.8		4	46	1.53 - 6.31	12/yr
Silicon	mg/L as Si	1.46	10	1.29	1.95		1.74	59	1.18 - 22.8	12/yr
Sulphate	mg/L as SO ₄	1.78	11	1.41	2.1	≤ 500 AO	1.57	96	<0.8 - 7.4	12/yr
Sulphide	mg/L as H ₂ S	<0.006	2	<0.005	<0.007	≤ 0.05 AO	<0.05	22	0.002 - <0.062	2/yr
Sulphur	mg/L as S	<3.0	10				0.6	70	<0.5 - 3.0	12/yr

mg/L = milligrams per litre
 ug/L = micrograms per litre
 ng/L = nanograms per litre

CFU = Colony Forming Units
 NTU = Nephelometric Units
 TCU = True Colour

AO = Aesthetic Objective
 MAC = Max. Acceptable Conc.
 Median = middle point of all values

TABLE 1. 2008 UNTREATED (RAW) WATER QUALITY AT JAPAN GULCH PLANT

(Guideline values provide reference only for untreated water)

PARAMETER		2008 ANALYTICAL RESULTS				2008 CANADIAN GUIDELINES	TEN YEAR RESULTS (1999-2008)			Target
Parameter	Units of	Median	Samples	Range		≤ = Less than or equal to	Ten Year	Samples	Range	Sampling
Name	Measure	Value	Analyzed	Minimum	Maximum		Median	Analyzed	Minimum-Maximum	Frequency
mg/L = parts per million ug/L = parts per billion ng/L = parts per trillion										
Metallic Inorganic Chemicals (< means less than instrument can detect)										
Aluminum	mg/L as Al	0.017	10	0.011	0.081	0.2 Operational Guideline	0.02	80	<0.008 - 0.17	10/yr
Antimony	mg/L as Sb	<0.005	10			0.006 MAC	<0.001	81	<0.000005 - <0.08	10/yr
Arsenic	mg/L as As	0.0001	10	<0.0001	0.0001	0.01 MAC	<0.001	82	0.0003 - <0.06	10/yr
Barium	mg/L as Ba	0.004	10	0.003	0.005	1.0 MAC	0.004	82	<0.002 - 0.04	10/yr
Beryllium	mg/L as Be	<0.0001	10				<0.0002	80	<0.0001 - <0.003	10/yr
Bismuth	mg/L as Bi	<0.001	9				<0.05	68	<0.001 - <0.05	10/yr
Boron	mg/L as B	<0.05	10	0.007	<0.05	5 MAC	<0.008	82	<0.002 - 0.33	10/yr
Cadmium	mg/L as Cd	0.00001	10	<0.00001	0.00005	0.005 MAC	<0.0001	81	<0.00001 - <0.006	10/yr
Calcium	mg/L as Ca	4.74	10	3.67	5.54	No Guideline Required	4.98	82	2.75 - 10.2	10/yr
Cerium	ug/L as Ce	Not analyzed in 2008					0.007	2	0.004 - 0.01	Irregular
Cesium	ug/L as Cs	Not analyzed in 2008					<0.029	2		Irregular
Chromium	mg/L as Cr	<0.001	10	<0.001	0.004	0.05 MAC	<0.005	80	0.0002 - 0.044	10/yr
Cobalt	mg/L as Co	<0.0005	10				<0.0005	81	0.00003 - 0.02	10/yr
Copper	mg/L as Cu	0.00065	10	0.0004	0.0011	≤ 1.0 AO	<0.005	79	0.0004 - 0.90	10/yr
Dysprosium	ug/L as Dy	Not analyzed in 2008					0.008	2	0.005 - 0.01	Irregular
Erbium	ug/L as Er	Not analyzed in 2008					0.005	2	0.0006 - <0.01	Irregular
Europium	ug/L as Eu	Not analyzed in 2008					0.001	2	0.00001 - <0.002	Irregular
Gallium	ug/L as Ga	Not analyzed in 2008					<0.05	2		Irregular
Gadolinium	ug/L as Gd	Not analyzed in 2008					<0.002	2		Irregular
Germanium	ug/L as Ge	Not analyzed in 2008					<0.001	2		Irregular
Gold	mg/L as Au	Not analyzed in 2008					<0.04	12	<0.0000001 - <0.04	Irregular
Hafnium	ug/L as Hf	Not analyzed in 2008					<0.005	2		Irregular
Holmium	ug/L as Ho	Not analyzed in 2008					0.002	2	0.0009 - <0.003	Irregular
Iron	mg/L as Fe	0.04	10	0.021	0.111	≤ 0.3 AO	0.042	82	0.018 - 0.17	10/yr
Lanthanum	mg/L as La	Not analyzed in 2008					<0.02	12	0.000003 - <0.02	Irregular
Lead	ug/L as Pb	<0.2	10	<0.2	0.6	10 MAC	<0.50	81	0.02 - <60	10/yr
Lithium	ug/L as Li	<5	10				<2	33	<0.06 - <5	10/yr
Lutetium	ug/L as Lu	Not analyzed in 2008					<0.0006	2		Irregular
Magnesium	mg/L as Mg	1.11	10	0.82	1.34	No Guideline Required	1.16	82	0.58 - 2.22	10/yr
Manganese	mg/L as Mn	0.006	10	<0.003	0.041	≤ 0.05 AO	0.008	82	<0.003 - 0.041	10/yr
Mercury, Methyl	ng/L as Hg	<0.001	4	<0.001	<0.01		<0.02	52	<0.01 - 0.087	4/yr
Mercury, Total	ug/L as Hg	0.00078	4	0.00043	0.00095	1 MAC	0.0009	84	0.00005 - 0.06	4/yr
Molybdenum	mg/L as Mo	<0.001	10				<0.005	82	<0.00006 - 0.02	12/yr
Neodymium	ug/L as Nd	Not analyzed in 2008					0.012	2	0.004 - <0.02	Irregular
Nickel	mg/L as Ni	<0.001	10	<0.001	0.003		<0.008	82	0.0002 - 0.066	10/yr
Phosphorus	mg/L as P	Not analyzed in 2008					<0.1	69	<0.02 - 0.219	10/yr
Potassium	mg/L as K	0.18	10	0.14	0.21		<1	85	0.006 - 1.09	10/yr
Praseodymium	ug/L as Pr	Not analyzed in 2008					<0.006	2	<0.002 - <0.01	Irregular
Rubidium	ug/L as Rb	Not analyzed in 2008					0.22	2		Irregular
Samarium	ug/L as Sm	Not analyzed in 2008					0.006	2	0.003 - <0.01	Irregular
Scandium	mg/L as Sc	Not analyzed in 2008					<0.05	12	<0.0009 - <0.05	Irregular

mg/L = milligrams per litre
ug/L = micrograms per litre
ng/L = nanograms per litre

CFU = Colony Forming Units
NTU = Nephelometric Units
TCU = True Colour

AO = Aesthetic Objective
MAC = Max. Acceptable Conc.
Median = middle point of all values

TABLE 1. 2008 UNTREATED (RAW) WATER QUALITY AT JAPAN GULCH PLANT

(Guideline values provide reference only for untreated water)

PARAMETER		2008 ANALYTICAL RESULTS				2008 CANADIAN GUIDELINES	TEN YEAR RESULTS (1999-2008)			Target
Parameter	Units of	Median	Samples	Range		≤ = Less than or equal to	Ten Year	Samples	Range	Sampling
Name	Measure	Value	Analyzed	Minimum	Maximum		Median	Analyzed	Minimum-Maximum	Frequency
mg/L = parts per million ug/L = parts per billion ng/L = parts per trillion										
Selenium	mg/L as Se	<0.0001	10			0.01 MAC	<0.001	84	<0.00005 - <0.5	10/yr
Silver	mg/L as Ag	<0.00002	10			No Guideline Required	<0.0001	81	<0.00001 - <0.01	10/yr
Sodium	mg/L as Na	1.63	10	1.4	1.90	≤ 200 AO	1.71	85	<0.05 - 2.6	10/yr
Strontium	mg/L as Sr	0.016	10	0.011	0.019		0.015	82	0.011 - 0.032	10/yr
Tantalum	ug/L as Ta	Not analyzed in 2008					<0.71	2		Irregular
Tellurium (52)	mg/L as Te	Not analyzed in 2008					<0.05	23		Irregular
Thallium	ug/L as Tl	<0.05	10				<0.1	70	0.01 - <30	10/yr
Thorium	ug/L as Th	Not analyzed in 2008					<0.001	2		Irregular
Thulium	ug/L as Tm	Not analyzed in 2008					0.0006	2	0.0001 - <0.001	Irregular
Tin	mg/L as Sn	<0.005	10				<0.02	72	<0.00002 - <0.06	10/yr
Titanium	mg/L as Ti	<0.005	10				<0.003	82	0.0006 - 0.012	10/yr
Tungsten	mg/L as W	Not analyzed in 2008					<0.05	12	0.000005 - <0.07	Irregular
Uranium	ug/L as U	<0.1	10			20 MAC	<0.1	41	<0.005 - <0.1	10/yr
Vanadium	mg/L as V	<0.005	10				<0.005	82	0.00018 - 0.01	10/yr
Ytterbium	ug/L as Yb	Not analyzed in 2008					0.005	2	0.0004 - <0.01	Irregular
Yttrium	ug/L as Yb	Not analyzed in 2008					0.023	2	0.006 - 0.04	Irregular
Zinc	mg/L as Zn	<0.005	10	<0.005	0.033	≤ 5.0 AO	<0.005	82	<0.0005 - 0.057	10/yr
Zirconium	ug/L as Zr	<5	10				<5	71	0.0004 - <5.0	10/yr

mg/L = milligrams per litre
ug/L = micrograms per litre
ng/L = nanograms per litre

CFU = Colony Forming Units
NTU = Nephelometric Units
TCU = True Colour

AO = Aesthetic Objective
MAC = Max. Acceptable Conc.
Median = middle point of all values

TABLE 1. 2008 UNTREATED (RAW) WATER QUALITY AT JAPAN GULCH PLANT

(Guideline values provide reference only for untreated water)

PARAMETER		2008 ANALYTICAL RESULTS				2008 CANADIAN GUIDELINES	TEN YEAR RESULTS (1999-2008)			Target
Parameter	Units of	Median	Samples	Range		≤ = Less than or equal to	Ten Year	Samples	Range	Sampling
Name	Measure	Value	Analyzed	Minimum	Maximum		Median	Analyzed	Minimum-Maximum	Frequency
mg/L = parts per million ug/L = parts per billion ng/L = parts per trillion										
Microbial Parameters (< means less than method or instrument can detect)										
Coliform Bacteria										
Coliform, Total	Coliforms/100 mL	16	249	<1	1,300		24	2,481	<1 - 15,000	250/yr
Coliform, Fecal	CFU/100 mL	Changed to E.coli analysis in 2004					<1	1,056	<1 - 18	Discontinued
<i>E. coli</i>	E.coli/100 mL	<1	249	<1	2		<1	1,464	<1 - 165	250/yr
Coliform, Background	CFU/100 mL	Discontinued in May, 2008					404	2,320	<1 - 109,278	Discontinued
Heterotrophic /Other Bacteria										
Hetero. Plate Count, 28C (7 day)	CFU/1 mL	390	248	60	3,600	No Guideline Required	400	2,448	<10 - 6,100	250/yr
Hetero. Plate Count, 35C (2 day)	CFU/1 mL	Discontinued in 2005				No Guideline Required	33	1,460	<1 - 1,500	Discontinued
<i>Aeromonas</i> species	CFU/100 mL	20	247	L10	1,120		128	1,242	<0.2 - 51,000	Special
<i>Enterococci</i>	CFU/100 mL	Discontinued in 2003					<1	39	<1 - 9	Discontinued
Cyanobacterial Toxins										
Anatoxin a	ug/L	Not analyzed in 2008					<0.2	6	<0.16 - <1.0	Special
Microcystin-LR	ug/L	<0.22	2			1.5 MAC	<0.22	10	<0.083 - <1.0	Special
Other Microcystins	ug/L	Not analyzed in 2008					<0.16	2		Special
Parasites										
						No MAC Established				
<i>Cryptosporidium</i> , Total oocysts	oocysts/100 L	0	6	0	1.6	Zero detection desirable	0	220	0 - 1.6	6/yr
<i>Cryptosporidium</i> , Viable oocysts	oocysts/100 L	0	6			Zero detection desirable	0	220	0 - 1	6/yr
<i>Giardia</i> , Total cysts	cysts/100 L	0	6			Zero detection desirable	0	220	0 - 2.9	6/yr
<i>Giardia</i> , Viable cysts	cysts/100 L	0	6			Zero detection desirable	0	220	0 - 2	6/yr
Radiological Parameters (< means less than instrument can detect)										
Gross alpha radiation	Bq/L	<0.015	2	<0.01	<0.02	0.1 (Screening)	<0.02	20	<0.01 - 0.07	2/yr
Gross beta radiation	Bq/L	0.025	2	<0.02	0.03	1.0 (Screening)	<0.02	20	<0.02 - 0.05	2/yr

mg/L = milligrams per litre
 ug/L = micrograms per litre
 ng/L = nanograms per litre

CFU = Colony Forming Units
 NTU = Nephelometric Units
 TCU = True Colour

AO = Aesthetic Objective
 MAC = Max. Acceptable Conc.
 Median = middle point of all values

TABLE 1. 2008 UNTREATED (RAW) WATER QUALITY AT JAPAN GULCH PLANT

(Guideline values provide reference only for untreated water)

PARAMETER		2008 ANALYTICAL RESULTS			2008 CANADIAN GUIDELINES	TEN YEAR RESULTS (1999-2008)			Target	
Parameter	Units of	Median	Samples	Range		≤ = Less than or equal to	Ten Year	Samples	Range	Sampling
Name	Measure	Value	Analyzed	Minimum	Maximum		Median	Analyzed	Minimum-Maximum	Frequency
mg/L = parts per million ug/L = parts per billion ng/L = parts per trillion										
Organic Parameters (< means less than instrument can detect)										
Pesticides/Herbicides										
1,4-DDD	ug/L	<0.01	2				<0.01	7		2/yr
1,4'-DDE	ug/L	<0.01	2				<0.01	20	<0.01 - <0.04	2/yr
1,4'-DDT	ug/L	<0.01	2			Guideline Archived	<0.01	20	<0.01 - <0.1	2/yr
2,4,5-T	ug/L	<0.1	2			Guideline Archived	<0.1	20	<0.1 - <0.5	2/yr
2,4,5-TP (Silvex)	ug/L	<0.1	2				<0.1	20	<0.1 - <0.5	2/yr
2,4-D	ug/L	<0.4	2			100 MAC	<0.4	20	<0.4 - <0.5	2/yr
2,4-DB	ug/L	<1.0	2				<1.0	20	<0.5 - <1.0	2/yr
3-Hydroxy Carbofuran	ug/L	<0.2	2				<0.2	20		2/yr
4,4'-DDD	ug/L	<0.03	2				<0.03	20	<0.03 - <0.1	2/yr
4,4'-DDE	ug/L	<0.01	2				<0.01	20	<0.01 - <0.04	2/yr
4,4'-DDT	ug/L	<0.01	2			Guideline Archived	<0.01	20	<0.01 - <0.1	2/yr
Alachlor	ug/L	<0.2	2				<0.2	20	<0.2 - <0.3	2/yr
Aldicarb	ug/L	<0.5	2			9.0 MAC	<0.5	20		2/yr
Aldicarb Sulfone	ug/L	<0.3	2				<0.3	20		2/yr
Aldicarb Sulfoxide	ug/L	<0.8	2				<0.8	20		2/yr
Aldrin	ug/L	<0.01	2			0.7 MAC	<0.01	20	<0.01 - <0.04	2/yr
Atrazine	ug/L	<0.1	2			5.0 MAC	<0.1	20	<0.1 - <0.2	2/yr
Azinphos-methyl	ug/L	<1.0	2			20 MAC	<1.0	20	<1.0 - <5.0	2/yr
BHC (alpha)	ug/L	<0.02	2				<0.02	20	<0.02 - <0.03	2/yr
BHC (beta)	ug/L	<0.03	1				<0.03	19	<0.03 - <0.06	2/yr
BHC (delta)	ug/L	<0.01	2				<0.01	20	<0.01 - <1.0	2/yr
Bendiocarb	ug/L	<0.2	2			40 MAC	<0.2	13	<0.2 - <1.0	2/yr
Bromacil	ug/L	<0.2	2				<0.2	20	<0.2 - <1.4	2/yr
Bromoxynil	ug/L	<0.02	2			5.0 MAC	<0.02	12		2/yr
Butylate	ug/L	<0.2	2				<0.2	20		2/yr
Carbaryl	ug/L	<0.2	2			90 MAC	<0.2	20		2/yr
Carbofuran	ug/L	<0.2	2			90 MAC	<0.2	20	<0.2 - <0.3	2/yr
Chlordane (alpha)	ug/L	<0.01	2			Guideline Archived	<0.01	20	<0.01 - <0.1	2/yr
Chlordane (gamma)	ug/L	<0.01	2			Guideline Archived	<0.01	20	<0.01 - <0.1	2/yr
Chlorfenvinphos	ug/L	<0.4	2				<0.4	20		2/yr
Chlorpropham	ug/L	<1.0	2				<1.0	20		2/yr
Chlorpyrifos	ug/L	<0.02	2			90 MAC	<0.02	20	<0.02 - <0.3	2/yr
Cyanazine	ug/L	<0.4	2			10 MAC	<0.4	2		2/yr
Demeton	ug/L	<0.8	2				<0.8	20		2/yr
Diazinon	ug/L	<0.03	2			20 MAC	<0.03	20	<0.03 - <0.2	2/yr
Dicamba	ug/L	<0.1	2			120 MAC	<0.1	20	<0.1 - <0.5	2/yr
Diclofop-methyl	ug/L	<0.5	2			9.0 MAC	<0.5	2		2/yr
Dieldrin	ug/L	<0.02	2				<0.02	20		2/yr
Dimethoate	ug/L	<0.2	2			20 MAC	<0.2	20	<0.2 - <0.4	2/yr

mg/L = milligrams per litre
ug/L = micrograms per litre
ng/L = nanograms per litre

CFU = Colony Forming Units
NTU = Nephelometric Units
TCU = True Colour

AO = Aesthetic Objective
MAC = Max. Acceptable Conc.
Median = middle point of all values

TABLE 1. 2008 UNTREATED (RAW) WATER QUALITY AT JAPAN GULCH PLANT

(Guideline values provide reference only for untreated water)

PARAMETER		2008 ANALYTICAL RESULTS				2008 CANADIAN GUIDELINES	TEN YEAR RESULTS (1999-2008)			Target
Parameter	Units of	Median	Samples	Range		≤ = Less than or equal to	Ten Year	Samples	Range	Sampling
Name	Measure	Value	Analyzed	Minimum	Maximum		Median	Analyzed	Minimum-Maximum	Frequency
mg/L = parts per million ug/L = parts per billion ng/L = parts per trillion										
Dinoseb	ug/L	<0.4	1			10 MAC	<0.4	1		Special
Dioxacarb	ug/L	<0.8	2				<0.8	20		2/yr
Diquat	ug/L	<1.0	2			70 MAC	<1.0	2		2/Yr
Disulfoton	ug/L	<0.2	2				<0.2	20		2/yr
Endosulfan I	ug/L	<0.01	2				<0.01	20	<0.01 - <0.1	2/yr
Endosulfan II	ug/L	<0.02	2				<0.02	20	<0.02 - <0.04	2/yr
Endosulfan Sulphate	ug/L	<0.02	2				<0.02	20	<0.02 - <0.7	2/yr
Endrin	ug/L	<0.02	2			Guideline Archived	<0.02	20	<0.02 - <0.06	2/yr
Endrin Aldehyde	ug/L	<0.05	2				<0.05	20	<0.05 - <0.2	2/yr
Ethion	ug/L	<0.3	2				<0.3	20		2/yr
Fenitrothion	ug/L	<0.5	2				<0.5	20		2/yr
Fenthion	ug/L	<0.6	2				<0.6	20		2/yr
Fonofos	ug/L	<0.2	2				<0.2	20		2/yr
Glyphosate	ug/L	<1.0	2			280 MAC	<35	20	<0.002 - <35	2/yr
Heptachlor	ug/L	<0.02	2			Guideline Archived	<0.02	20	<0.02 - <0.3	2/yr
Heptachlor Epoxide	ug/L	<0.01	2			Guideline Archived	<0.01	20	<0.01 - <0.8	2/yr
Hexazinone	ug/L	<0.8	2				<0.8	20		2/yr
Isofenphos	ug/L	<0.4	2				<0.4	20		2/yr
Lindane (BHC-gamma)	ug/L	<0.01	2			Guideline Archived	<0.01	20	<0.01 - <0.04	2/yr
Malathion	ug/L	<0.2	2			190 MAC	<0.2	20	<0.5 - <0.6	2/yr
MCPA	ug/L	<0.1	2				<50	20	<0.1 - <50	2/yr
MCPP	ug/L	<0.1	2				<100	20	<0.1 - <100	2/yr
Methidathion	ug/L	<0.3	2				<0.3	20		2/yr
Methiocarb	ug/L	<0.3	2				<0.3	20		2/yr
Methomyl	ug/L	<0.3	2				<0.3	20		2/yr
Methoxychlor	ug/L	<0.04	2			900 MAC	<0.04	20	<0.04 - <2.0	2/yr
Methyl-Parathion	ug/L	<0.2	2			Guideline Archived	<0.2	20		2/yr
Metolachlor	ug/L	<0.8	2			50 MAC	<0.8	20		2/yr
Mevinphos	ug/L	<0.4	2				<0.4	20		2/yr
Monocrotophos	ug/L	<1.0	2				<1.0	20		2/yr
Nitritotriacetic acid (NTA)	mg/L	<0.4	2			0.4 MAC	<0.4	2		2/yr
Oxamyl	ug/L	<0.3	2				<0.3	20		2/yr
Parathion	ug/L	<0.2	2			50 MAC	<0.2	20		2/yr
Paraquat	ug/L	<1.0	2			10 MAC	<1.0	2		2/yr
Phorate	ug/L	<0.2	2			2.0 MAC	<0.2	20		2/yr
Phosalone	ug/L	<1.0	2				<1.0	20		2/yr
Phosmet	ug/L	<5.0	2				<5.0	20		2/yr
Picloram	ug/L	<0.1	2			190 MAC	<0.1	20	<0.1 - <0.2	2/yr
Promecarb	ug/L	<0.2	2				<0.2	20		2/yr
Propazine	ug/L	<0.1	2				<0.1	20		2/yr
Propoxur	ug/L	<0.2	2				<0.2	20		2/yr

mg/L = milligrams per litre
ug/L = micrograms per litre
ng/L = nanograms per litre

CFU = Colony Forming Units
NTU = Nephelometric Units
TCU = True Colour

AO = Aesthetic Objective
MAC = Max. Acceptable Conc.
Median = middle point of all values

TABLE 1. 2008 UNTREATED (RAW) WATER QUALITY AT JAPAN GULCH PLANT

(Guideline values provide reference only for untreated water)

PARAMETER		2008 ANALYTICAL RESULTS				2008 CANADIAN GUIDELINES	TEN YEAR RESULTS (1999-2008)			Target
Parameter	Units of	Median	Samples	Range		≤ = Less than or equal to	Ten Year	Samples	Range	Sampling
Name	Measure	Value	Analyzed	Minimum	Maximum		Median	Analyzed	Minimum-Maximum	Frequency
mg/L = parts per million ug/L = parts per billion ng/L = parts per trillion										
Simazine	ug/L	<0.1	2			10 MAC	<0.1	20		2/yr
Terbufos	ug/L	<0.5	2			1.0 MAC	<0.5	20	<0.5 - <0.9	2/yr
Tetrachlovinphos	ug/L	<0.2	2				<0.2	20		2/yr
Toxaphene	ug/L	<0.08	2			Guideline Archived	<0.08	20	<0.08 - <3.0	2/yr
Trifluralin	ug/L	<0.03	1			45 MAC	<0.03	1		Special
Polycyclic Aromatic Hydrocarbons (PAH's)										
Acenaphthene	ug/L	<0.4	2			Guideline Archived	<0.4	20		2/yr
Acenaphthylene	ug/L	<0.7	2			Guideline Archived	<0.7	20		2/yr
Acridine	ug/L	<0.3	2			Guideline Archived	<0.3	20		2/yr
Anthracene	ug/L	<0.2	2			Guideline Archived	<0.2	20		2/yr
Benzo(a)anthracene	ug/L	<0.3	2			Guideline Archived	<0.3	20		2/yr
Benzo(a)pyrene	ug/L	<0.01	2			0.01 MAC	<0.01	20	<0.01 - <0.5	2/yr
Benzo(b)fluoranthene	ug/L	<0.6	2			Guideline Archived	<0.6	20		2/yr
Benzo(g,h,i)perylene	ug/L	<0.5	2			Guideline Archived	<0.5	20		2/yr
Benzo(k)fluoranthene	ug/L	<0.5	2			Guideline Archived	<0.5	20		2/yr
Chrysene	ug/L	<0.4	2			Guideline Archived	<0.4	20		2/yr
Dibenz(a,h)anthracene	ug/L	<0.3	2			Guideline Archived	<0.3	20		2/yr
Fluoranthene	ug/L	<0.3	2			Guideline Archived	<0.3	20		2/yr
Fluorene	ug/L	<0.4	2			Guideline Archived	<0.4	20		2/yr
Indeno(1,2,3-c,d)pyrene	ug/L	<0.5	2			Guideline Archived	<0.5	20		2/yr
Naphthalene	ug/L	<0.6	2			Guideline Archived	<0.6	20		2/yr
Phenanthrene	ug/L	<0.3	2			Guideline Archived	<0.3	20		2/yr
Pyrene	ug/L	<0.2	2			Guideline Archived	<0.2	20		2/yr

mg/L = milligrams per litre
ug/L = micrograms per litre
ng/L = nanograms per litre

CFU = Colony Forming Units
NTU = Nephelometric Units
TCU = True Colour

AO = Aesthetic Objective
MAC = Max. Acceptable Conc.
Median = middle point of all values

TABLE 1. 2008 UNTREATED (RAW) WATER QUALITY AT JAPAN GULCH PLANT

(Guideline values provide reference only for untreated water)

PARAMETER		2008 ANALYTICAL RESULTS				2008 CANADIAN GUIDELINES	TEN YEAR RESULTS (1999-2008)			Target
Parameter	Units of	Median	Samples	Range		≤ = Less than or equal to	Ten Year	Samples	Range	Sampling
Name	Measure	Value	Analyzed	Minimum	Maximum		Median	Analyzed	Minimum-Maximum	Frequency
mg/L = parts per million ug/L = parts per billion ng/L = parts per trillion										
Phenols										
2,3,4,5-Tetrachlorophenol	ug/L	<0.05	2				<0.05	20		2/yr
2,3,4,6-Tetrachlorophenol	ug/L	<0.05	2			100 MAC and ≤ 1.0 AO	<0.05	20		2/yr
2,3,4-Trichlorophenol	ug/L	<0.1	2				<0.1	20		2/yr
2,3,5-Trichlorophenol	ug/L	<0.1	2				<0.1	20		2/yr
2,3,6-Trichlorophenol	ug/L	<0.1	2				<0.1	20		2/yr
2,3-Dichlorophenol	ug/L	<0.1	2				<1.0	19	<0.1 - <1.0	2/yr
2,4,5-Trichlorophenol	ug/L	<0.1	2				<0.1	20		2/yr
2,4,6-Trichlorophenol	ug/L	<0.1	2			5.0 MAC and ≤ 2.0 AO	<0.1	20		2/yr
2,4-Dichlorophenol	ug/L	<0.1	2			900 MAC and ≤ 0.3 AO	<1.0	19	<0.1 - <1.0	2/yr
2,4-Dimethylphenol	ug/L	<0.5	2				<2.0	17	<0.5 - <2.0	2/yr
2,4-Dinitrophenol	ug/L	<0.5	2				<10	17	<0.5 - <10	2/yr
2,5-Dichlorophenol	ug/L	<0.1	2				<1.0	19	<0.1 - <1.0	2/yr
2,6-Dichlorophenol	ug/L	<0.1	2				<1.0	19	<0.1 - <1.0	2/yr
2-Chlorophenol	ug/L	<0.1	2				<1.0	19	<0.1 - <1.0	2/yr
2-Methylphenol	ug/L	<0.5	2				<2.0	17	<0.5 - <2.0	2/yr
2-Nitrophenol	ug/L	<0.5	2				<2.0	17	<0.5 - <2.0	2/yr
3,4,5-Trichlorophenol	ug/L	<0.1	2				<0.1	20		2/yr
3,4-Dichlorophenol	ug/L	<0.1	2				<1.0	19	<0.1 - <1.0	2/yr
3,5-Dichlorophenol	ug/L	<0.1	2				<1.0	19	<0.1 - <1.0	2/yr
3-Chlorophenol	ug/L	<0.1	2				<1.0	19	<0.1 - <1.0	2/yr
4,6-Dinitro-2-methylphenol	ug/L	<0.5	1				<10	16	<0.5 - <10	2/yr
4-Chloro-3-Methylphenol	ug/L	<1.0	2				<1.0	4		2/yr
4-Chlorophenol	ug/L	<0.1	2				<1.0	18	<0.1 - <1.0	2/yr
4-Methylphenol	ug/L	<0.5	2				<3.0	17	<0.5 - <3.0	2/yr
4-Nitrophenol	ug/L	<0.5	2				<2.0	17	<0.5 - <2.0	2/yr
Pentachlorophenol	ug/L	<0.05	2			60 MAC and ≤ 30 AO	<0.05	20		2/yr
Phenol	ug/L	<0.5	2				<1.0	17	<0.5 - <1.0	2/yr
Total Phenolics	mg/L	<0.001	2			Guideline Archived	0.002	18	<0.001 - 0.004	2/yr
Total Trichlorophenols	ug/L	<0.1	2				<0.1	19	<0.05 - <0.1	2/yr
Total Tetrachlorophenols	ug/L	<0.05	2				<0.05	19		2/yr
Total Chlorinated Phenols	ug/L	<0.05	2				<0.05	19	<0.05 - <0.1	2/yr

mg/L = milligrams per litre
ug/L = micrograms per litre
ng/L = nanograms per litre

CFU = Colony Forming Units
NTU = Nephelometric Units
TCU = True Colour

AO = Aesthetic Objective
MAC = Max. Acceptable Conc.
Median = middle point of all values

TABLE 1. 2008 UNTREATED (RAW) WATER QUALITY AT JAPAN GULCH PLANT

(Guideline values provide reference only for untreated water)

PARAMETER		2008 ANALYTICAL RESULTS				2008 CANADIAN GUIDELINES	TEN YEAR RESULTS (1999-2008)			Target
Parameter Name	Units of Measure	Median Value	Samples Analyzed	Range Minimum Maximum		≤ = Less than or equal to	Ten Year Median	Samples Analyzed	Range Minimum-Maximum	Sampling Frequency
mg/L = parts per million ug/L = parts per billion ng/L = parts per trillion										
Other Synthetic Chemicals										
1,1,1-Trichloroethane	ug/L	<0.1	2				<0.1	20		2/yr
1,1,2,2-Tetrachloroethane	ug/L	<0.2	2				<0.2	20		2/yr
1,1,2-Trichloroethane	ug/L	<0.1	2				<0.1	20		2/yr
1,1-Dichloroethane	ug/L	<0.1	2				<0.1	20		2/yr
1,1-Dichloroethylene	ug/L	<0.1	2			14 MAC	<0.1	19		2/yr
1,2,4-Trichlorobenzene	ug/L	<0.5	2				<0.5	20		2/yr
1,2-Dibromoethane	ug/L	<0.005	2				<0.1	20	<0.005 - <0.1	2/yr
1,2-Dichlorobenzene	ug/L	<0.1	2			200 MAC and ≤ 3.0 AO	<0.1	20		2/yr
1,2-Dichloroethane	ug/L	<0.2	2	<0.005	<0.4	5.0 MAC	<0.4	20	<0.005 - <0.4	2/yr
1,2-Dichloroethylene (cis)	ug/L	<0.1	2				<0.1	20		2/yr
1,2-Dichloroethylene (trans)	ug/L	<0.1	2				<0.1	20		2/yr
1,2-Dichloropropane	ug/L	<0.1	2				<0.1	20		2/yr
1,3-Dichlorobenzene	ug/L	<0.1	2				<0.1	20		2/yr
1,3-Dichloropropene (cis)	ug/L	<0.1	2				<0.1	20		2/yr
1,3-Dichloropropene (trans)	ug/L	<0.1	2				<0.1	20		2/yr
1,4-Dichlorobenzene	ug/L	<0.1	2			5.0 MAC and ≤ 1.0 AO	<0.1	20		2/yr
2,4-Dinitrotoluene	ug/L	<0.7	2				<0.7	20		2/yr
2,6-Dinitrotoluene	ug/L	<2.0	2				<2.0	20		2/yr
2-Butanone	ug/L	<5.0	2				<5.0	20		2/yr
2-Chloronaphthalene	ug/L	<0.7	2				<0.7	20		2/yr
2-Hexanone	ug/L	<20	2				<5.0	20	<5.0 - <20	2/yr
2-Methylnaphthalene	ug/L	<3.0	2				<3.0	20		2/yr
2-Nitroaniline	ug/L	<4.0	2				<4.0	20	<4.0 - <5.0	2/yr
3,3'-Dichlorobenzidine	ug/L	<3.0	2				<3.0	20		2/yr
3-Nitroaniline	ug/L	<3.0	2				<3.0	20		2/yr
4-Bromophenyl-phenylether	ug/L	<0.3	2				<0.3	20		2/yr
4-Chloroaniline	ug/L	<5.0	2				<5.0	19		2/yr
4-Chlorophenyl-phenylether	ug/L	<0.4	2				<0.4	20		2/yr
4-Methyl-2-pentanone	ug/L	<2.0	2				<2.0	20		2/yr
4-Nitroaniline	ug/L	<4.0	2				<4.0	20		2/yr
Aminomethylphosphonic Acid (AMPA)	ug/L	<1.0	2				<35	18	<1.0 - <35	2/yr
Aniline	ug/L	<5.0	2				<5.0	20		2/yr
Azobenzene	ug/L	<0.6	2				<0.6	20		2/yr
Benzene	ug/L	<0.1	2			5.0 MAC	<0.1	21	<0.01 - <0.1	2/yr
Benzyl Alcohol	ug/L	<3.0	2				<3.0	20		2/yr
Bis (-2-chloroethoxy)methane	ug/L	<0.6	2				<0.6	20	<0.5 - <0.6	2/yr
Bis (-2-chloroethyl)ether	ug/L	<0.6	2				<0.6	20		2/yr
Bis (2-chloroisopropyl)ether	ug/L	<0.5	2				<0.5	20		2/yr
Bis (2-ethylhexyl) phthalate	ug/L	<0.6	2	<0.3	<0.8		<8.0	21	<0.3 - 31	2/yr

mg/L = milligrams per litre
 ug/L = micrograms per litre
 ng/L = nanograms per litre

CFU = Colony Forming Units
 NTU = Nephelometric Units
 TCU = True Colour

AO = Aesthetic Objective
 MAC = Max. Acceptable Conc.
 Median = middle point of all values

TABLE 1. 2008 UNTREATED (RAW) WATER QUALITY AT JAPAN GULCH PLANT

(Guideline values provide reference only for untreated water)

PARAMETER		2008 ANALYTICAL RESULTS				2008 CANADIAN GUIDELINES	TEN YEAR RESULTS (1999-2008)			Target
Parameter	Units of	Median	Samples	Range		≤ = Less than or equal to	Ten Year	Samples	Range	Sampling
Name	Measure	Value	Analyzed	Minimum	Maximum		Median	Analyzed	Minimum-Maximum	Frequency
mg/L = parts per million ug/L = parts per billion ng/L = parts per trillion										
Bisphenol A (BPA)	ug/L	<0.1	1				<0.1	1		Special
Bromomethane	ug/L	<0.8	2				<0.8	20		2/yr
Butylbenzyl phthalate	ug/L	<9.0	2				<9.0	20		2/yr
Carbon Tetrachloride	ug/L	<0.1	2			5.0 MAC	<0.1	20		2/yr
Chloroethane	ug/L	<0.4	2				<0.4	20		2/yr
Chloromethane	ug/L	<0.4	2				<0.4	19		2/yr
Dibenzofuran	ug/L	<2.0	2				<2.0	20		2/yr
Dibromomethane	ug/L	<0.2	2				<0.2	20		2/yr
Dichlorodifluoromethane	ug/L	<0.2	2				<0.2	20		2/yr
Diethyl phthalate	ug/L	<0.3	2				<0.3	20		2/yr
Dimethyl phthalate	ug/L	<0.6	2				<0.6	20		2/yr
Di-n-butyl phthalate	ug/L	<30	2				<30	20		2/yr
Di-n-ocyl phthalate	ug/L	<0.8	2				<0.8	20		2/yr
Diuron	ug/L	<0.5	2			150 MAC	<0.5	14		2/yr
Ethylbenzene	ug/L	<0.1	2			≤ 2.4 AO	<0.1	21	<0.01 - <0.1	2/yr
Formaldehyde	mg/L	<0.1	2			No Guideline Required	<0.1	16		2/yr
Hexachlorobenzene	ug/L	<0.4	2				<0.4	20		2/yr
Hexachlorobutadiene	ug/L	<2.0	2				<2.0	20		2/yr
Hexachlorocyclopentadiene	ug/L	<5.0	2				<5.0	20		2/yr
Hexachloroethane	ug/L	<2.0	2				<2.0	20		2/yr
Isophorone	ug/L	<1.0	2				<1.0	20		2/yr
Methylene Chloride	ug/L	<6.0	2				<6.0	20		2/yr
Methyl-tert-butyl-ether (MTBE)	ug/L	Not analyzed in 2008				15 AO	<0.5	12		Special
Metribuzin	ug/L	<0.2	2			80 MAC	<0.2	2		2/yr
Monochlorobenzene	ug/L	<0.1	2			80 MAC and ≤ 30 AO	<0.1	20		2/yr
N-nitrosodimethylamine (NDMA)	ug/L	<0.002	1				<0.002	2	<0.002 - 0.002	Special
Nitrobenzene	ug/L	<0.9	2				<0.9	20	<0.9 - <1.0	2/yr
N-nitroso-di-n-propylamine	ug/L	<8.0	2				<8.0	20		2/yr
N-nitrosodiphenylamine	ug/L	<0.3	2				<0.3	20		2/yr
Styrene	ug/L	<0.1	2				<0.1	20		2/yr
Tetrachloroethylene	ug/L	<0.1	2			30 MAC	<0.1	20		2/yr
Toluene	ug/L	<0.1	2			≤ 24 AO	<0.1	21	<0.01 - <0.1	2/yr
Trichloroethylene	ug/L	<0.1	2			5.0 MAC	<0.1	20		2/yr
Trichlorofluoromethane	ug/L	<0.2	2				<0.2	20		2/yr
Vinyl Chloride	ug/L	<0.2	2			2.0 MAC	<0.2	20		2/yr
o-Xylene	ug/L	Not analyzed in 2008					<0.01	1		Special
m&p-Xylene	ug/L	Not analyzed in 2008					<0.01	1		Special
Xylenes (Total)	ug/L	<0.1	2			≤ 300 AO	<0.1	20		2/yr

mg/L = milligrams per litre
ug/L = micrograms per litre
ng/L = nanograms per litre

CFU = Colony Forming Units
NTU = Nephelometric Units
TCU = True Colour

AO = Aesthetic Objective
MAC = Max. Acceptable Conc.
Median = middle point of all values