

Table 5.
 Location Class: R5M OAK BAY DISTRIBUTION SYSTEM

Location Class	Month	Bacterial Water Samples Collected	Total Coliforms				E.coli Samples > 0 CFU/100mL	Fecal Coliforms Samples FC > 0 CFU/100mL	Turbidity		Chlorine Residual Monthly Median mg/L as Cl2	Water Temperature Monthly Median Degrees C.
			Samples TC > 0 CFU/100mL	TC > 0 Percent	Resamples TC > 0 CFU/100mL	Samples TC > 10 CFU/100mL			Samples Collected	Adverse > 1 NTU		
OAK BAY DISTRIBUTION SYSTEM R5M	JAN	17	0	.0%	0	0	0	2	0	.71	6.3	
	FEB	14	0	.0%	0	0	0	2	0	.77	6.7	
	MAR	14	0	.0%	0	0	0	2	0	.74	8.1	
	APR	15	0	.0%	0	0	0	2	0	.72	9.2	
	MAY	16	0	.0%	0	0	0	2	0	.80	11.5	
	JUN	13	0	.0%	0	0	0	1	0	.69	14.2	
	JUL	17	0	.0%	0	0	0	3	0	.83	16.5	
	AUG	15	1	6.7%	0	0	0	2	0	.64	18.1	
	SEP	14	0	.0%	0	0	0	2	0	.55	18.2	
	OCT	18	1	5.6%	0	0	0	1	0	.54	14.0	
	Totals	153	2	1.3%	0	0	0	19	0	.69	12.4	

NOTES: > = Greater than, TC = Total Coliforms, FC = Fecal Coliforms, TCBK = Background colonies on a Total Coliform membrane filter, CFU = Colony Forming Units

COMMENTS: One sample collected from Willows Beach Concession on October 9th was found positive for coliforms. The resample collected on October 10th was negative for coliforms.