

Monthly TABLE 2. - Adverse Review

Sampling Dates: 01-APR-2012 to 30-APR-2012

Greater Victoria Distribution System		Total Coliforms		T.C.Background		Fecal Coli		E. Coli		Chlorine Residual mg/L		Turbidity	
Municipality/Area	Samples Collected	Samples Positive	Percent Positive	Samples Collected	Bkg > 200	Samples Positive	Percent Positive	Samples Positive	Percent Positive	Cl2 less than 0.1	Cl2 less than 0.2	Samples Collected	Adverse > 1 NTU
R1M	CENTRAL SAANICH DISTRIBL	25	0	0	25	0		0	0	0	1	5	0
R2M	SAANICH DISTRIBUTION SYS	37	0	0	28	0		0	0	2	5	6	1
R3M	NORTH SAANICH DISTRIBUTI	17	0	0	16	0		0	0	2	3	1	0
R4M	VICTORIA DISTRIBUTION SYS	30	1	3.3	13	0		0	0	0	0	10	1
R5M	OAK BAY DISTRIBUTION SYS	14	0	0	12	0		0	0	0	0	2	0
R6M	SIDNEY DISTRIBUTION SYSTI	10	0	0	5	0		0	0	0	0	0	0
R9M	WESTSHORE. DISTRIBUTION	38	0	0	19	0		0	0	3	7	5	0
Distribution System Totals/Averages:		171	1	0.6	118	0		0	0	7	16	29	2

Sooke Distribution System		Total Coliforms		T.C.Background		Fecal Coli		E. Coli		Chlorine Residual mg/L		Turbidity	
Municipality/Area	Samples Collected	Samples Positive	Percent Positive	Samples Collected	Bkg > 200	Samples Positive	Percent Positive	Samples Positive	Percent Positive	Cl2 less than 0.1	Cl2 less than 0.2	Samples Collected	Adverse > 1 NTU
R7M	SOOKE DISTRIBUTION SYSTI	14	0	0	12	0		0	0	0	5	0	0
Distribution System Totals/Averages:		14	0	0	12	0		0	0	0	5	0	0

COMMENTS: There was one total coliform positive result in the Greater Victoria distribution system in April. The resample was negative for total coliforms. There were no adverse bacteriological results in the samples collected from the Sooke distribution system in April.