

2012 Bacteriological Summary

Location Class: GVIC GR. VICTORIA DISTRIBUTION SYSTEM

Location Class	Month	Bacterial Water Samples Collected	Total Coliforms			E.coli Samples > 0 CFU/100mL	Fecal Coliforms Samples FC > 0 CFU/100mL	Turbidity		Chlorine Residual Monthly Median mg/L as Cl2	Water Temperature Monthly Median Degrees C.
			Samples TC > 0 CFU/100mL	TC > 0 Percent	Resamples TC > 0 CFU/100mL			Samples TC > 10 CFU/100mL	Samples Collected		
GR. VICTORIA DISTRIBUTION SYSTEM	JAN	170	1	.6%	0	0	0	20	0	.99	6.7
GVIC	FEB	189	0	.0%	0	0	0	26	0	.83	6.8
	MAR	190	0	.0%	0	0	0	31	1	.63	7.2
	APR	171	1	.6%	0	0	0	29	2	.62	9.2
	Totals	720	2	.3%	0	0	0	106	3	.75	7.3

NOTES: > = Greater than, TC = Total Coliforms, FC = Fecal Coliforms, TCBK = Background colonies on a Total Coliform membrane filter, CFU = Colony Forming Units

COMMENTS: There was one total coliform positive result in the Greater Victoria distribution system in April. The resample was negative for total coliforms.