

Inquiries at: 474-9680

Location Class: R7M SOOKE DISTRIBUTION SYSTEM

Reporting Period: 01-JAN-2012 to 30-APR-2012

Report to _____

Remark Codes !NW No Water at the tap
!SI Point Inaccessible
L Less than
POF Pump OFF(sampl.pt)
PON Pump is ON(sampl pt)
RC Reconfirmed

Station Description	Total Coliform	E. coli	TC Presence	Ecoli Presence	Chlorine	Water Temp	Turbidity	Colour	HPC Count	
Sampling Point	Limit= 0/100mL	Limit= 0/100mL	Limit = Absent	Limit = Absent	Limit = 3.0	Limit = 15	Limit = 1	Limit = 15	Limit = 10,000	
Location Code	CFU or MPN	CFU or MPN	Present/Absent	Present/Absent	mg/L as Cl2	Degrees C	NTU	TCU	CFU/mL	
Date	Time	TC	ECOLI	TCPA	ECPA	FCL2T	WTEMP	TURB	COLTR	HPC7D
2615 Otter Pt. Rd	10-JAN-2012	13:10	0	0		.18	6.2			L 10
Quick connectn meter box	24-JAN-2012	10:45	0	0		RC.17	5.8			10
SOK-BR-04	07-FEB-2012	09:35	0	0		.27	6.3			
	21-FEB-2012	10:07	0	0		.32	6.3			
	06-MAR-2012	09:40	0	0		RC.09	6.1	.26		L 10
	06-MAR-2012	10:40				.11	6.8			
	20-MAR-2012	10:12	0	0		.13	6.6			L 10
	03-APR-2012	10:06	0	0		.21	7.1			
	17-APR-2012	09:49	0	0		RC.14	8.5			70
Coppermine Rd Pumphouse	05-JAN-2012	10:11	0	0		PON1.12	7.8			
red box sample station	18-JAN-2012	12:39	0	0		POF 1.02	6.3			
SOK-ES-01	01-FEB-2012	10:48	0	0		PON1.11	6.7	.3	4.4	
	15-FEB-2012	11:24	0	0		PON1.04	7.6			
	29-FEB-2012	10:16	0	0		PON1.04	7.1			
	14-MAR-2012	11:31	0	0		POF .96	7.7			
	28-MAR-2012	10:02	0	0		POF .99	8.3			
	11-APR-2012	11:52	0	0		POF .94	8.8			
	25-APR-2012	10:20	0	0		POF .28	10.7			
Andover & Llanilar pump	05-JAN-2012	10:31			Absent	Absent	POF .31	9.8		
sample tap inside phouse	18-JAN-2012	12:55			Absent	Absent	PON .68	4.8		
SOK-ES-02	01-FEB-2012	11:42			Absent	Absent	POF .56	7.3		
	15-FEB-2012	11:40			Absent	Absent	POF .8	7.2		
	29-FEB-2012	10:30			Absent	Absent	POF .54	7.2		
	14-MAR-2012	11:44			Absent	Absent	POF .6	6.7		
	28-MAR-2012	11:04			Absent	Absent	PON .53	8.3		
	11-APR-2012	12:09			Absent	Absent	POF .16	9.2		190
	25-APR-2012	10:54			Absent	Absent	POF .1	10.2		90

Station Description Sampling Point Location Code	Date	Time	Total Coliform Limit= 0/100mL CFU or MPN TC	E. coli Limit= 0/100mL CFU or MPN ECOLI	TC Presence Limit = Absent Present/Absent TCPA	Ecoli Presence Limit = Absent Present/Absent ECPA	Chlorine Limit = 3.0 mg/L as Cl2 FCL2T	Water Temp Limit = 15 Degrees C WTEMP	Turbidity Limit = 1 NTU TURB	Colour Limit = 15 TCU COLTR	HPC Count Limit = 10,000 CFU/mL HPC7D
next to 6450 E Sooke Rd	05-JAN-2012	10:47	0	0			1.11	7.3			
QC under manhole lid	18-JAN-2012	13:11	0	0			1.06	5.8			
SOK-ES-03	01-FEB-2012	12:27	0	0			1.19	6.4			
	15-FEB-2012	11:54	0	0			1.23	6.8			
	29-FEB-2012	10:45	0	0			1.04	6.8			
	14-MAR-2012	11:54	0	0			.99	7			
	28-MAR-2012	11:12	0	0			.99	7.4			
	11-APR-2012	12:46	0	0			.92	8			
	25-APR-2012	11:08	0	0			RC .31	10.1			
Henlyn Road pumphouse	10-JAN-2012	13:28	0	0			PON .77	7.6			
hosebib on pres. gauge	24-JAN-2012	11:10	0	0			POF .5	6.7			
SOK-JM-01	07-FEB-2012	09:50	0	0			RC .22	POF7.6			
	21-FEB-2012	10:21	0	0			RC .2	POF7.6			80
	06-MAR-2012	10:30	0	0			POF .29	7.6			
	20-MAR-2012	11:14	0	0			RC .23	7.5			
	03-APR-2012	:					!NW				
	17-APR-2012	11:01	0	0			PON .15	9.2			170
Ayum Road Pumphouse	04-JAN-2012	08:15	0	0			PON 1.02	8.7			
Red box wall of pumphse	17-JAN-2012	07:30	0	0			PON .93	6.6			
SOK-SA-02	31-JAN-2012	07:35	0	0			RC .81	PON7.2			
	14-FEB-2012	08:00	0	0			PON .91	7.3			
	28-FEB-2012	08:15	0	0			PON .96	6.7			
	13-MAR-2012	07:43	0	0			.91	7.6			
	27-MAR-2012	08:28	0	0			PON .82	8.4			
	11-APR-2012	08:47	0	0			PON .71	9.1			
	24-APR-2012	08:35	0	0			PON .18	10.6			80

Station Description Sampling Point Location Code	Date	Time	Total Coliform Limit= 0/100mL CFU or MPN TC	E. coli Limit= 0/100mL CFU or MPN ECOLI	TC Presence Limit = Absent Present/Absent TCPA	Ecoli Presence Limit = Absent Present/Absent ECPA	Chlorine Limit = 3.0 mg/L as Cl2 FCL2T	Water Temp Limit = 15 Degrees C WTEMP	Turbidity Limit = 1 NTU TURB	Colour Limit = 15 TCU COLTR	HPC Count Limit = 10,000 CFU/mL HPC7D
2075 Otter Pt. Rd.	04-JAN-2012	09:00	0	0			1.12	6.6			
Quick connect-green lid	17-JAN-2012	08:45	0	0			1.08	5.1			
SOK-SV-02	31-JAN-2012	09:00	0	0			1.09	5.4			
	14-FEB-2012	09:23	0	0			1.07	5.2			
	28-FEB-2012	09:10	0	0			1.11	5.2			
	13-MAR-2012	09:01	0	0			1.09	5.8			
	27-MAR-2012	09:42	0	0			1.01	6.3			
	11-APR-2012	:					!SI				
	13-APR-2012	12:10					.94	9.7			
	24-APR-2012	09:51	0	0			.32	9.4			
1528 Whiffen Spit Rd.	04-JAN-2012	09:30	0	0			.62	8.4			
green box @ meter	17-JAN-2012	09:25	0	0			.52	7.3			
SOK-WS-02	31-JAN-2012	09:45	0	0			.71	6.9			
	14-FEB-2012	09:57	0	0			.75	7.4			
	28-FEB-2012	09:45	0	0			.66	6.6			
	13-MAR-2012	09:28	0	0			.72	6.8			
	27-MAR-2012	10:10	0	0			.66	7.2			
	11-APR-2012	10:00	0	0			.58	8.2			
	24-APR-2012	10:43	0	0			.2	9.9			780
Grand Totals											
Overall Statistics	04-JAN-2012	Samples	59	59	9	9	70	70	2	1	11
for Location Class	to	Mean	0	0	0	0	.67	7.43	.28	4.4	133.64
R7M	25-APR-2012	Minimum	0	0	0	0	.09	4.8	.26	4.4	0
SOOKE DISTRIBUTION SYSTEM		Maximum	0	0	0	0	1.23	10.7	.3	4.4	780
		Median	0	0	0	0	.715	7.25	.28	4.4	80
		Percent Positive	0.0%	0.0%							