

Report to \_\_\_\_\_

Remark Codes !NR No water in Reserv  
 !NW No Water at the tap  
 !SI Point Inaccessible  
 A Approximate  
 L Less than  
 PON Pump is ON(sampl pt)  
 RC Reconfirmed  
 RES Resample;Special

Station Description	Total Coliform	E. coli	TC Presence	Ecoli Presence	Chlorine	Water Temp	Turbidity	Colour	HPC Count	
Sampling Point	Limit= 0/100mL	Limit= 0/100mL	Limit = Absent	Limit = Absent	Limit = 3.0	Limit = 15	Limit = 1	Limit = 15	Limit = 10,000	
Location Code	CFU or MPN	CFU or MPN	Present/Absent	Present/Absent	mg/L as Cl2	Degrees C	NTU	TCU	CFU/mL	
Date	Time	TC	ECOLI	TCPA	ECPA	FCL2T	WTEMP	TURB	COLTR	HPC7D
Bear Mtn Res cell1 left	11-JAN-2012	11:31		Absent	Absent	1.31	6.2			
2109 Nicklaus Dr	27-JAN-2012	13:01		Absent	Absent	1.27	5.6			
BMR-01-02	08-FEB-2012	12:45		Absent	Absent	1.26	6.6			
	22-FEB-2012	13:06		Absent	Absent	.87	6.4			
	07-MAR-2012	13:10		Absent	Absent	.81	6.3			
	21-MAR-2012	11:35		Absent	Absent	1.06	6.6			
	04-APR-2012	12:56		Absent	Absent	RC 1.01	7.2			
	18-APR-2012	11:21		Absent	Absent	.99	8.5			
Bear Mtn Res cell2 right	11-JAN-2012	11:29		Absent	Absent	1.3	6.3			
Sample box on wall	27-JAN-2012	13:03		Absent	Absent	1.35	5.8			
BMR-02-02	08-FEB-2012	12:42		Absent	Absent	1.22	6.8			
	22-FEB-2012	13:04		Absent	Absent	.87	6.5			
	07-MAR-2012	13:20		Absent	Absent	.8	6.4			
	21-MAR-2012	11:38		Absent	Absent	RC 1.43	6.5			
	04-APR-2012	12:58		Absent	Absent	RC 1.07	7.3			
	18-APR-2012	11:18		Absent	Absent	.97	8.5			
Cloake Hill Reservoir	05-JAN-2012	11:00	0	0		1.01	7.4	.31	4.6	
QC under hatch	18-JAN-2012	13:00	0	0		.99	6.1	.25	5.2	
CLR-01-01	01-FEB-2012	11:05	0	0		1.07	6.1	.31	4.6	
	15-FEB-2012	11:08	0	0		1.01	5.7	.3	3.6	
	16-FEB-2012	11:08				1.01				
	29-FEB-2012	11:20	0	0		.64	6.2	.31	3.5	
	14-MAR-2012	11:29	0	0		.57	6.1	.43	4.5	
	28-MAR-2012	11:14	0	0		.8	6.7	.32	3.3	
	12-APR-2012	11:20	0	0		.75	7.6	.26	4.5	
	25-APR-2012	11:20	0	0		.72	8.3	.45	3.1	

Station Description Sampling Point Location Code	Date	Time	Total Coliform Limit= 0/100mL CFU or MPN TC	E. coli Limit= 0/100mL CFU or MPN ECOLI	TC Presence Limit = Absent Present/Absent TCPA	Ecoli Presence Limit = Absent Present/Absent ECPA	Chlorine Limit = 3.0 mg/L as Cl2 FCL2T	Water Temp Limit = 15 Degrees C WTEMP	Turbidity Limit = 1 NTU TURB	Colour Limit = 15 TCU COLTR	HPC Count Limit = 10,000 CFU/mL HPC7D
Coppermine Rd Reservoir red box on res. wall CRR-01-02	05-JAN-2012	10:20	0	0			.85	6.8			
	18-JAN-2012	:					!SI				
	01-FEB-2012	11:29	0	0			.83	6.4			
	15-FEB-2012	11:33	0	0			.85	7.1			
	29-FEB-2012	10:23	0	0			.81	6.2			
	14-MAR-2012	11:36	0	0			.84	6.3			
	28-MAR-2012	10:11	0	0			.77	7.4			
	11-APR-2012	12:01	0	0			.37	9.2			
	25-APR-2012	10:31	0	0			.22	9.9			
Cromwell Res (Mt Tolmie) Sample tube in box - 1M CRR-SA-01	09-JAN-2012	10:35			Absent	Absent	.29	7.1			
	23-JAN-2012	10:20			Absent	Absent	.4	6.2			
	06-FEB-2012	07:50			Absent	Absent	.35	5.7			
	20-FEB-2012	09:27			Absent	Absent	.33	6.1			
	05-MAR-2012	09:55			Absent	Absent	.32	7.1			
	19-MAR-2012	09:59			Absent	Absent	.43	6.7			
	02-APR-2012	09:49			Absent	Absent	.34	7.7			
	16-APR-2012	10:05			Absent	Absent	.2	9.1			1620
	30-APR-2012	09:53			Absent	Absent	.18	10.3			A4600
Deer park Trail reser. Red box 3M below TWL DKR-01-03	05-JAN-2012	11:42			Absent	Absent	.17	7			10
	18-JAN-2012	:					!SI				
	01-FEB-2012	10:28			Absent	Absent	1.33	5.7			
	15-FEB-2012	10:51			Absent	Absent	.82	6.8			
	29-FEB-2012	09:47			Absent	Absent	.8	5.9			
	14-MAR-2012	11:03			Absent	Absent	.92	6.1			
	28-MAR-2012	12:09			Absent	Absent	.87	7.8			
	11-APR-2012	11:20			Absent	Absent	.81	8.9			
	25-APR-2012	12:01			Absent	Absent	.65	10.7			

Station Description Sampling Point Location Code	Date	Time	Total Coliform Limit= 0/100mL CFU or MPN TC	E. coli Limit= 0/100mL CFU or MPN ECOLI	TC Presence Limit = Absent Present/Absent TCPA	Ecoli Presence Limit = Absent Present/Absent ECPA	Chlorine Limit = 3.0 mg/L as Cl2 FCL2T	Water Temp Limit = 15 Degrees C WTEMP	Turbidity Limit = 1 NTU TURB	Colour Limit = 15 TCU COLTR	HPC Count Limit = 10,000 CFU/mL HPC7D
Dean Pk Res (Upper)	03-JAN-2012	12:05	1	0			PON .45	7			
Upper	05-JAN-2012	12:35	RES0	0			.34	7.2			
DPR-U1-01	09-JAN-2012	12:50	0	0			PON .44	6.6			
	16-JAN-2012	10:45	0	0			PON .21	6.3			
	23-JAN-2012	12:20	0	0			PON .25	5.8			
	30-JAN-2012	12:10	0	0			PON .45	5.7			
	06-FEB-2012	10:10	0	0			PON .4	5.7			
	13-FEB-2012	12:24	0	0			PON .58	6.5			
	16-FEB-2012	12:24					.58				
	20-FEB-2012	11:44	0	0			PON .28	5.3			
	27-FEB-2012	12:00	0	0			PON .33	5.3			
	05-MAR-2012	11:40	0	0			PON .27	5.8			
	12-MAR-2012	:					!SI				
	14-MAR-2012	10:10	0	0			PON .17	5.7			
	19-MAR-2012	11:51	0	0			RC .17	PON5.8			A 2500
	26-MAR-2012	12:07	0	0			PON .28	5.9			
	02-APR-2012	11:32	0	0			PON .42	6.3			
	10-APR-2012	12:03	0	0			PON .3	6.8			
	16-APR-2012	11:51	0	0			PON .24	7.3			
	23-APR-2012	12:17	0	0			PON .38	8.7			
	30-APR-2012	11:40	0	0			PON .43	8.4			
Fulton Res Cell 1	12-JAN-2012	14:02	0	0			.86	7.6			
Tap in Fire PH SS Line	26-JAN-2012	09:30	0	0			.93	6			
FUR-01-01	09-FEB-2012	11:10	0	0			.76	6.8			
	23-FEB-2012	08:47	0	0			.69	6.1			
	08-MAR-2012	09:16	0	0			.67	6.3			
	22-MAR-2012	09:32	0	0			.48	6.3			
	05-APR-2012	08:50	0	0			.58	7			
	19-APR-2012	09:25	0	0			.48	8			

Station Description Sampling Point Location Code	Date	Time	Total Coliform Limit= 0/100mL CFU or MPN TC	E. coli Limit= 0/100mL CFU or MPN ECOLI	TC Presence Limit = Absent Present/Absent TCPA	Ecoli Presence Limit = Absent Present/Absent ECPA	Chlorine Limit = 3.0 mg/L as Cl2 FCL2T	Water Temp Limit = 15 Degrees C WTEMP	Turbidity Limit = 1 NTU TURB	Colour Limit = 15 TCU COLTR	HPC Count Limit = 10,000 CFU/mL HPC7D
Fulton Res Cell 2	12-JAN-2012	14:14	0	0			.9	7.4			
Tap in Fire PH SS Line	26-JAN-2012	09:40	0	0			1.05	5.8			
FUR-02-01	09-FEB-2012	11:15	0	0			.86	6.3			
	23-FEB-2012	08:47	0	0			.76	5.9			
	08-MAR-2012	09:20	0	0			.73	6.6			
	22-MAR-2012	09:32	0	0			.54	6.2			
	05-APR-2012	09:00	0	0			.6	7.1			
	19-APR-2012	09:37	0	0			.54	8.1			
Haliburton res NE Corner	13-JAN-2012	12:01			Absent	Absent	.03	7.6			80
5M below TWL Tap @ Basmt	27-JAN-2012	10:30			Absent	Absent	RC .02	7.3			10
HAR-02-05	10-FEB-2012	09:15			Absent	Absent	RC .17	6.6			20
	24-FEB-2012	10:20			Absent	Absent	.03	5.8			470
	09-MAR-2012	11:35			Absent	Absent	.04	5.7			10
	23-MAR-2012	10:53					!NW				
	04-APR-2012	10:49			Absent	Absent	RC .81	6			
	20-APR-2012	10:57			Absent	Absent	.54	6.6			
Helgeson Res Far-E Cel A	10-JAN-2012	12:30			Absent	Absent	.58	5.9			
Sampbox on W Wall 2M TWL	24-JAN-2012	10:30					!NR				
HER-CA-02	07-FEB-2012	09:00			Absent	Absent	.68	6.4			
	21-FEB-2012	09:34			Absent	Absent	.56	6.3			
	06-MAR-2012	09:50			Absent	Absent	.55	6.1			
	20-MAR-2012	10:25			Absent	Absent	.59	6.6			
	03-APR-2012	10:35			Absent	Absent	.41	7.2			
	17-APR-2012	10:20			Absent	Absent	.35	8.4			
Helgeson Res Mid-E Cel B	10-JAN-2012	12:45			Absent	Absent	.68	5.8			
Sampbox on E Wall 2M TWL	24-JAN-2012	10:32					!NR				
HER-CB-02	07-FEB-2012	09:05			Absent	Absent	.72	6.6			
	21-FEB-2012	09:44			Absent	Absent	.61	6.3			
	06-MAR-2012	10:00			Absent	Absent	.64	6.6			
	20-MAR-2012	10:43			Absent	Absent	.65	6.5			
	03-APR-2012	10:50			Absent	Absent	.38	7.3			
	17-APR-2012	10:28			Absent	Absent	.25	8.9			

Inquiries at: 474-9680

Location Class: R8 D/S RESERVOIRS (includes Sooke)

Reporting Period: 01-JAN-2012 to 30-APR-2012

File: 701-15-

Station Description Sampling Point Location Code	Date	Time	Total Coliform Limit= 0/100mL CFU or MPN TC	E. coli Limit= 0/100mL CFU or MPN ECOLI	TC Presence Limit = Absent Present/Absent TCPA	Ecoli Presence Limit = Absent Present/Absent ECPA	Chlorine Limit = 3.0 mg/L as Cl2 FCL2T	Water Temp Limit = 15 Degrees C WTEMP	Turbidity Limit = 1 NTU TURB	Colour Limit = 15 TCU COLTR	HPC Count Limit = 10,000 CFU/mL HPC7D
Helgeson Res Mid-W Cel C	10-JAN-2012	12:55			Absent	Absent	.43	6.3			
Tap on RT hatch 2M TWL	24-JAN-2012	10:35			Absent	Absent	.61	5.5			
HER-CC-02	07-FEB-2012	09:15			Absent	Absent	.68	6.8			
	21-FEB-2012	09:45			Absent	Absent	.54	5.8			
	06-MAR-2012	10:05			Absent	Absent	.54	6.3			
	20-MAR-2012	10:55			Absent	Absent	.55	6.5			
	03-APR-2012	10:25			Absent	Absent	.41	7.2			
	17-APR-2012	10:40			Absent	Absent	.37	8.5			
Helgeson Res Far-W Cel D	10-JAN-2012	12:58			Absent	Absent	.39	6.3			
Tap on LT hatch 2M TWL	24-JAN-2012	10:38			Absent	Absent	.47	5.6			
HER-CD-02	07-FEB-2012	09:20			Absent	Absent	.6	6.7			
	21-FEB-2012	09:45			Absent	Absent	.58	5.8			
	06-MAR-2012	10:10			Absent	Absent	.47	6.4			
	20-MAR-2012	10:55			Absent	Absent	.5	6.6			
	03-APR-2012	10:25			Absent	Absent	.39	7.2			
	17-APR-2012	10:45			Absent	Absent	.29	8.6			
Hartland Reservoir	09-JAN-2012	13:50			Absent	Absent	.7	6.3			
tap under lid in front	23-JAN-2012	13:25			Absent	Absent	.64	5.2			
HLR-01-01	06-FEB-2012	11:10			Absent	Absent	.75	5.8			
	20-FEB-2012	13:13			Absent	Absent	.13	5.6			200
	05-MAR-2012	12:35			Absent	Absent	.33	5.9			
	19-MAR-2012	13:03			Absent	Absent	.33	5.9			
	02-APR-2012	12:27			Absent	Absent	.46	6.7			
	16-APR-2012	12:45			Absent	Absent	.34	8.3			
	30-APR-2012	12:37			Absent	Absent	.38	9.7			
Henlyn Res 7194 Cedar Pk	04-JAN-2012	09:20	0	0			RC.44	7.2			
Tap in Box on Res Wall	17-JAN-2012	09:05	0	0			.48	4.3			
HRR-02-01	31-JAN-2012	09:25	0	0			.38	5.4			
	14-FEB-2012	09:33	0	0			.32	6.3			
	28-FEB-2012	09:25	0	0			.34	5.1			
	13-MAR-2012	09:10	0	0			.39	5.6			
	27-MAR-2012	09:54	0	0			.38	7.6			
	11-APR-2012	09:43	0	0			.11	9.6			130
	24-APR-2012	10:20	0	0			RC.05	11.2			2240

Station Description			Total Coliform	E. coli	TC Presence	Ecoli Presence	Chlorine	Water Temp	Turbidity	Colour	HPC Count
Sampling Point	Date	Time	Limit= 0/100mL	Limit= 0/100mL	Limit = Absent	Limit = Absent	Limit = 3.0	Limit = 15	Limit = 1	Limit = 15	Limit = 10,000
Location Code			CFU or MPN	CFU or MPN	Present/Absent	Present/Absent	mg/L as Cl2	Degrees C	NTU	TCU	CFU/mL
			TC	ECOLI	TCPA	ECPA	FCL2T	WTEMP	TURB	COLTR	HPC7D
McTavish Lower Reservoir	06-JAN-2012	12:20	0	0			1.32	6.7			
Hosebib on outlet line	19-JAN-2012	12:24	0	0			1.19	5			
MCR-L1-01	02-FEB-2012	10:40	0	0			1.17	5.4			
	16-FEB-2012	11:03	0	0			1.1	5.3			
	01-MAR-2012	09:55	0	0			.67	5.6			
	15-MAR-2012	11:28	0	0			RC .59	5.7			
	29-MAR-2012	10:03	0	0			.74	6.2			
	13-APR-2012	11:10	0	0			1.01	7.1			
	26-APR-2012	10:53	0	0			.98	8.1			
McTavish Upper Reservoir	06-JAN-2012	12:35	0	0			1.24	6.6			
Hosebib u/s of meter	19-JAN-2012	12:31	0	0			1.24	4.8			
MCR-U1-01	02-FEB-2012	11:00	0	0			1.3	5.5			
	16-FEB-2012	11:17	0	0			1.27	5.4			
	01-MAR-2012	10:10	0	0			.66	5.7			
	15-MAR-2012	11:35	0	0			1.11	5.8			
	29-MAR-2012	10:18	0	0			1.22	6.2			
	13-APR-2012	11:23	0	0			1	7	.45		
	26-APR-2012	11:10	0	0			.99	8.2			
Mt Tolmie Res inlet(S)	03-JAN-2012	10:15	0	0			1.08	6.9			
SW samp can 2M below TWL	16-JAN-2012	10:45	0	0			1.01	5.7			
MTR-G1-12	30-JAN-2012	10:10	0	0			.99	5.4			
	13-FEB-2012	10:36	0	0			1.03	5.8			
	27-FEB-2012	10:35	0	0			.85	5.1			
	12-MAR-2012	10:41	0	0			.78	5.8			
	26-MAR-2012	10:55	0	0			.81	6			
	10-APR-2012	10:45	0	0			.6	7.2			
	23-APR-2012	10:49	0	0			.69	9.2			

Station Description			Total Coliform	E. coli	TC Presence	Ecoli Presence	Chlorine	Water Temp	Turbidity	Colour	HPC Count
Sampling Point	Date	Time	Limit= 0/100mL	Limit= 0/100mL	Limit = Absent	Limit = Absent	Limit = 3.0	Limit = 15	Limit = 1	Limit = 15	Limit = 10,000
Location Code			CFU or MPN	CFU or MPN	Present/Absent	Present/Absent	mg/L as Cl2	Degrees C	NTU	TCU	CFU/mL
			TC	ECOLI	TCPA	ECPA	FCL2T	WTEMP	TURB	COLTR	HPC7D
Mt Tolmie Res outlet(N)	03-JAN-2012	10:00	0	0			.69	7.1			
NE samp can 2M below TWL	16-JAN-2012	10:30	0	0			.65	6			
MTR-G2-32	30-JAN-2012	09:55	0	0			.99	5.8			
	13-FEB-2012	10:35	0	0			.84	5.7			
	27-FEB-2012	10:25	0	0			.67	5.1			
	12-MAR-2012	10:27	0	0			.57	5.9			
	26-MAR-2012	10:44	0	0			.72	6.2			
	10-APR-2012	10:29	0	0			.49	7			
	23-APR-2012	10:35	0	0			.4	8.6			
Saan Mt Tolmie main Res.	09-JAN-2012	10:55			Absent	Absent	.72	6.6			
NE Cnr Res roof 2M depth	23-JAN-2012	10:30			Absent	Absent	.62	5.8			
MTR-SA-02	06-FEB-2012	08:00			Absent	Absent	.7	5.1			
	20-FEB-2012	09:43			Absent	Absent	.68	5.1			
	05-MAR-2012	10:05			Absent	Absent	.5	5.9			
	19-MAR-2012	10:22			Absent	Absent	.68	5.6			
	02-APR-2012	10:07			Absent	Absent	.57	6.3			
	16-APR-2012	10:26			Absent	Absent	.34	7.8			
	30-APR-2012	10:11			Absent	Absent	.33	8.7			
Peacock Reservoir Cell 1	03-JAN-2012	12:08	RES0	0			.61	5.8			
Metal box on front wall	11-JAN-2012	12:30			Absent	Absent	.7	3.7			
PER-01-01	25-JAN-2012	12:43			Absent	Absent	.41	4			
	08-FEB-2012	11:52			Absent	Absent	.25	6.2			
	22-FEB-2012	12:12			Absent	Absent	.34	5.6			
	07-MAR-2012	11:50			Absent	Absent	.02	4.6			1570
	21-MAR-2012	10:04			Absent	Absent	.09	4.4			A 5000
	04-APR-2012	12:13			Absent	Absent	.12	6.6			A 5000
	18-APR-2012	10:26			Absent	Absent	.03	9.5			A 5400
Peacock Reservoir Cell 2	11-JAN-2012	12:41			Absent	Absent	.38	4.7			
Metal box on back wall	25-JAN-2012	12:51			Absent	Absent	.4	4			
PER-02-01	08-FEB-2012	11:55			Absent	Absent	.24	6.2			
	22-FEB-2012	12:15			Absent	Absent	.23	5.8			
	07-MAR-2012	11:52			Absent	Absent	.18	5.3			50
	21-MAR-2012	10:08			Absent	Absent	.26	5.5			
	04-APR-2012	12:15			Absent	Absent	.12	7.1			A 2000
	18-APR-2012	10:29			Absent	Absent	.04	9.6			3220

Inquiries at: 474-9680

Location Class: R8 D/S RESERVOIRS (includes Sooke)

Reporting Period: 01-JAN-2012 to 30-APR-2012

File: 701-15-

Station Description Sampling Point Location Code	Date	Time	Total Coliform Limit= 0/100mL CFU or MPN TC	E. coli Limit= 0/100mL CFU or MPN ECOLI	TC Presence Limit = Absent Present/Absent TCPA	Ecoli Presence Limit = Absent Present/Absent ECPA	Chlorine Limit = 3.0 mg/L as Cl2 FCL2T	Water Temp Limit = 15 Degrees C WTEMP	Turbidity Limit = 1 NTU TURB	Colour Limit = 15 TCU COLTR	HPC Count Limit = 10,000 CFU/mL HPC7D
Rithet Reservoir, Inlet	11-JAN-2012	12:47			Absent	Absent	1.25	5.7			
Down Pipe tap	25-JAN-2012	11:50			Absent	Absent	1.47	4.6			
RIR-01-01	08-FEB-2012	10:45			Absent	Absent	1.34	5.6			
	22-FEB-2012	11:21			Absent	Absent	.4	5.9			
	07-MAR-2012	10:40			Absent	Absent	.98	5.1			
	21-MAR-2012	11:04			Absent	Absent	.99	5.1			
	04-APR-2012	10:17			Absent	Absent	1.09	6.2			
	18-APR-2012	10:59			Absent	Absent	1.17	6.8			
Rithet Res, Inlet/Outlet	11-JAN-2012	12:50			Absent	Absent	1.24	5.8			
Ground level tap	25-JAN-2012	11:55			Absent	Absent	1.21	4.5			
RIR-02-01	08-FEB-2012	10:50			Absent	Absent	1.19	5.4			
	22-FEB-2012	11:21			Absent	Absent	.72	5.1			
	07-MAR-2012	10:45			Absent	Absent	.67	5.2			
	21-MAR-2012	11:13			Absent	Absent	1.02	5.3			
	04-APR-2012	10:17			Absent	Absent	1.02	6.1			
	18-APR-2012	11:13			Absent	Absent	1	7			
Rocky Point Res-outlet	05-JAN-2012	11:57			Absent	Absent	RC.47	7.3	.3	3.4	
red box 3M below TWL	18-JAN-2012	:					!SI				
ROR-01-03	01-FEB-2012	10:17			Absent	Absent	1.44	6.6	.29	5	
	15-FEB-2012	10:36			Absent	Absent	1.24	6.7			
	29-FEB-2012	09:38			Absent	Absent	1.28	6.6	.28	4.5	
	14-MAR-2012	10:48			Absent	Absent	1.24	6.2			
	28-MAR-2012	12:23			Absent	Absent	1.36	7.8	.28	2.8	
	11-APR-2012	11:03			Absent	Absent	1.15	8.3			
	25-APR-2012	12:16					1.1	10.7	.26	3.8	
Silverspray Res. Cell 1	05-JAN-2012	11:01			Absent	Absent	.11	6.5			10
Samp Box 3M Below TWL	18-JAN-2012	13:11					!SI				
SIR-01-03	01-FEB-2012	12:45					!NW				
	15-FEB-2012	:					!NR				
	29-FEB-2012	:					!NR				
	14-MAR-2012	:					!NR				
	28-MAR-2012	:					!NR				
	11-APR-2012	12:46					!NR				
	25-APR-2012	:						INR			

Station Description Sampling Point Location Code	Date	Time	Total Coliform Limit= 0/100mL CFU or MPN TC	E. coli Limit= 0/100mL CFU or MPN ECOLI	TC Presence Limit = Absent Present/Absent TCPA	Ecoli Presence Limit = Absent Present/Absent ECPA	Chlorine Limit = 3.0 mg/L as Cl2 FCL2T	Water Temp Limit = 15 Degrees C WTEMP	Turbidity Limit = 1 NTU TURB	Colour Limit = 15 TCU COLTR	HPC Count Limit = 10,000 CFU/mL HPC7D
Silverspray Res. Cell 2	05-JAN-2012	:					!NR				
Samp Box 3M Below TWL	18-JAN-2012	13:11					!NR				
SIR-02-03	01-FEB-2012	12:08			Absent	Absent	.92	5.6			
	15-FEB-2012	12:18			Absent	Absent	.57	6.2			
	29-FEB-2012	10:56			Absent	Absent	.53	6.3			
	14-MAR-2012	12:05			Absent	Absent	.5	6.4			
	28-MAR-2012	11:24			Absent	Absent	.51	6.9			
	11-APR-2012	12:30			Absent	Absent	RC .16	8.3			10
	25-APR-2012	11:22			Absent	Absent	RC .01	10.1			1260
Skirt Mtn Res Cell 1	11-JAN-2012	10:51	0	0			.66	5.7			
Rt. Tap to front of cell	25-JAN-2012	:									
SKM-01-02	27-JAN-2012	12:41	0	0			.69	6.1			
	08-FEB-2012	:									
	08-FEB-2012	12:22	0	0			.69	7.8			
	22-FEB-2012	12:42	0	0			.48	6.6			
	07-MAR-2012	12:31	0	0			.42	6.3			
	21-MAR-2012	11:09	0	0			.58	8.3			
	04-APR-2012	12:37	0	0			.55	7.2			
	18-APR-2012	11:00	0	0			.47	8.2			
Skirt Mtn Res Cell 3	11-JAN-2012	:					!NR				
Rt. Tap to front of cell	22-FEB-2012	:					!NR				
SKM-03-02	07-MAR-2012	:					!NW				
	21-MAR-2012	11:09					!NR				
	04-APR-2012	:					!NR				
	18-APR-2012	11:00					!NR				
Stirrup Reservoir Cell 1	12-JAN-2012	13:41			Absent	Absent	.06	5.8			400
Metal enclosure in front	26-JAN-2012	09:00			Absent	Absent	.15	4.3			660
SPR-01-02	09-FEB-2012	10:21			Absent	Absent	.11	7.3			720
	23-FEB-2012	08:15			Absent	Absent	.1	6			60
	08-MAR-2012	08:50			Absent	Absent	.07	6.2			1010
	22-MAR-2012	08:49			Absent	Absent	.17	6.7			L 10
	05-APR-2012	08:15			Absent	Absent	.1	7.7			290
	19-APR-2012	09:03			Absent	Absent	.08	10.2			470

Station Description Sampling Point Location Code	Date	Time	Total Coliform Limit= 0/100mL CFU or MPN TC	E. coli Limit= 0/100mL CFU or MPN ECOLI	TC Presence Limit = Absent Present/Absent TCPA	Ecoli Presence Limit = Absent Present/Absent ECPA	Chlorine Limit = 3.0 mg/L as Cl2 FCL2T	Water Temp Limit = 15 Degrees C WTEMP	Turbidity Limit = 1 NTU TURB	Colour Limit = 15 TCU COLTR	HPC Count Limit = 10,000 CFU/mL HPC7D
Stirrup Reservoir Cell 2 Metal box on front wall SPR-02-02	12-JAN-2012	13:39			Absent	Absent	.07	5.4			280
	26-JAN-2012	09:05			Absent	Absent	RC .06	4.2			730
	09-FEB-2012	10:19			Absent	Absent	.08	7.5			700
	23-FEB-2012	08:15			Absent	Absent	.05	5.6			10
	08-MAR-2012	08:55			Absent	Absent	.03	6.1			1080
	22-MAR-2012	08:58			Absent	Absent	.29	6.6			
	05-APR-2012	08:25			Absent	Absent	.08	8.2			260
	19-APR-2012	09:10			Absent	Absent	.08	10.7			640
Sunriver Res Cell 1 Sp 2 NW Corner SRR-01-02	10-JAN-2012	:					!NR				
	24-JAN-2012	10:05	0	0			.81	5			
	07-FEB-2012	08:25	0	0			.87	5.9			
	21-FEB-2012	09:01	0	0			.77	5.8			
	06-MAR-2012	09:15	0	0			.78	6.1			
	20-MAR-2012	09:40	0	0			.75	6.4			
	03-APR-2012	09:40	0	0			.59	7.3			
	17-APR-2012	09:27	0	0			.48	9.1			
Sunriver Res Cell 2 Sp 2 NE Corner SRR-02-02	10-JAN-2012	11:58	0	0			.82	6.2			
	24-JAN-2012	10:10					!NR				
	07-FEB-2012	08:30					!NR				
	06-MAR-2012	09:10					!NR				
	20-MAR-2012	:					!NR				
	03-APR-2012	:					!NR				
	17-APR-2012	09:27					!NW				
Upper Dawson Reservoir Tap on inlet/outlet line UDR-01-01	06-JAN-2012	11:25	0	0			.86	7.2			
	20-JAN-2012	11:46					!SI				
	03-FEB-2012	11:07	0	0			.96	8.5			
	17-FEB-2012	10:43	0	0			.8	8.3			
	20-FEB-2012	12:40	0	0			.28	5.8			
	02-MAR-2012	10:50	0	0			.55	6.2			
	16-MAR-2012	10:31	0	0			.47	6.4			
	30-MAR-2012	10:17	0	0			.61	6.8			
	13-APR-2012	10:40	0	0			.63	7.8			
	27-APR-2012	10:33	0	0			.74	8.5			

Station Description Sampling Point Location Code	Date	Time	Total Coliform Limit= 0/100mL CFU or MPN TC	E. coli Limit= 0/100mL CFU or MPN ECOLI	TC Presence Limit = Absent Present/Absent TCPA	Ecoli Presence Limit = Absent Present/Absent ECPA	Chlorine Limit = 3.0 mg/L as Cl2 FCL2T	Water Temp Limit = 15 Degrees C WTEMP	Turbidity Limit = 1 NTU TURB	Colour Limit = 15 TCU COLTR	HPC Count Limit = 10,000 CFU/mL HPC7D
Walfred Res Inlet W Wall	03-JAN-2012	07:55			Absent	Absent	.08	6.7			20
North cell 2M below TWL	16-JAN-2012	12:51			Absent	Absent	.12	4.3			110
WAR-01-02	30-JAN-2012	07:50			Absent	Absent	.11	5.3			30
	13-FEB-2012	08:15			Absent	Absent	.1	5.6			50
	27-FEB-2012	08:40			Absent	Absent	.06	5.4			40
	12-MAR-2012	09:35			Absent	Absent	.08	5.8			A 3920
	26-MAR-2012	08:46			Absent	Absent	.14	6.3			90
	10-APR-2012	08:49			Absent	Absent	.08	7.2			2370
	23-APR-2012	08:52			Absent	Absent	.06	8.3			A 7800
Walfred Res Outlet S Wall	03-JAN-2012	07:58			Absent	Absent	.01	6.6			10
South cell 2M below TWL	16-JAN-2012	12:55			Absent	Absent	.14	4.2			
WAR-03-02	30-JAN-2012	07:55			Absent	Absent	.08	5.2			40
	13-FEB-2012	08:21			Absent	Absent	.03	5.4			10
	27-FEB-2012	08:45			Absent	Absent	.04	5.2			10
	12-MAR-2012	08:47			Absent	Absent	.05	5.7			A 6100
	26-MAR-2012	08:56			Absent	Absent	.11	6.2			10
	10-APR-2012	08:59			Absent	Absent	.05	7.1			3300
	23-APR-2012	08:59			Absent	Absent	.05	8.2			A 8600
Whisperwind Res.Cell 1	11-JAN-2012	12:58			Absent	Absent	1.14	5.3			
Tap in box-wall of res.	25-JAN-2012	11:54			Absent	Absent	1.16	4.6			
WHR-01-02	08-FEB-2012	13:12			Absent	Absent	1.14	7.8			
	22-FEB-2012	13:27			Absent	Absent	1.03	6.8			
	07-MAR-2012	13:38			Absent	Absent	.79	7.1			
	21-MAR-2012	12:14			Absent	Absent	1.02	6			
	04-APR-2012	13:22			Absent	Absent	.84	8			
	18-APR-2012	11:48			Absent	Absent	.63	10.5			
Whisperwind Res.Cell 2	11-JAN-2012	13:05			Absent	Absent	1.04	5.1			
Tap in box-wall of res.	25-JAN-2012	12:00			Absent	Absent	1.08	4.5			
WHR-02-01	08-FEB-2012	13:15			Absent	Absent	1.05	7.6			
	22-FEB-2012	13:29			Absent	Absent	.86	6.6			
	07-MAR-2012	13:35			Absent	Absent	.68	7.1			
	21-MAR-2012	12:11			Absent	Absent	.98	6			
	04-APR-2012	13:20			Absent	Absent	.78	7.9			
	18-APR-2012	11:50			Absent	Absent	.72	10.4			

			Total Coliform	E. coli	TC Presence	Ecoli Presence	Chlorine	Water Temp	Turbidity	Colour	HPC Count
			Limit= 0/100mL	Limit= 0/100mL	Limit = Absent	Limit = Absent	Limit = 3.0	Limit = 15	Limit = 1	Limit = 15	Limit = 10,000
			CFU or MPN	CFU or MPN	Present/Absent	Present/Absent	mg/L as Cl2	Degrees C	NTU	TCU	CFU/mL
<b>Grand Totals</b>			TC	ECOLI	TCPA	ECPA	FCL2T	WTEMP	TURB	COLTR	HPC7D
Overall Statistics	03-JAN-2012	Samples	123	123	185	185	311	309	15	14	54
for Location Class	to	Mean	.01	0	0	0	.61	6.6	.32	4.03	1393.15
R8	30-APR-2012	Minimum	0	0	0	0	.01	3.7	.25	2.8	0
D/S RESERVOIRS (includes Sooke)		Maximum	1	0	0	0	1.47	11.2	.45	5.2	8600
		Median	0	0	0	0	.59	6.3	.3	4.15	345
		Percent Positive	0.8%	0.0%							

End of Report: BACTXLC8