

Report to _____

Remark Codes !SI Point Inaccessible
 A Approximate
 L Less than
 POF Pump OFF(sampl.pt)
 PON Pump is ON(sampl pt)
 RC Reconfirmed

Station Description	Total Coliform	E. coli	TC Presence	Ecoli Presence	Chlorine	Water Temp	Turbidity	Colour	HPC Count	
Sampling Point	Limit= 0/100mL	Limit= 0/100mL	Limit = Absent	Limit = Absent	Limit = 3.0	Limit = 15	Limit = 1	Limit = 15	Limit = 10,000	
Location Code	CFU or MPN	CFU or MPN	Present/Absent	Present/Absent	mg/L as Cl2	Degrees C	NTU	TCU	CFU/mL	
Date	Time	TC	ECOLI	TCPA	ECPA	FCL2T	WTEMP	TURB	COLTR	HPC7D
Pelican Dr Pumphouse	11-JAN-2012	09:46	0	0						
Tap @ Sink in Pumphouse	25-JAN-2012	10:50	0	0						
COL-AH-01	08-FEB-2012	11:31	0	0		PON1.23	7.8			
	22-FEB-2012	11:28	0	0		PON1.13	6.6			
	07-MAR-2012	12:31	0	0		POF 1.06	6.2			
	21-MAR-2012	13:57	0	0		POF .96	7.6			
	04-APR-2012	11:52	0	0		POF .89	7.8			
	18-APR-2012	10:05	0	0		PON .81	9.5			
Childrens Activity Centr	12-JAN-2012	14:25	0	0		.07	7.8	.32	16	50
Galiano Cr QC in Metrbox	26-JAN-2012	10:30	0	0		RC.01	6.6			10
COL-CO-02	09-FEB-2012	11:40	0	0		RC0	7.3	.27	14	970
	23-FEB-2012	09:32	0	0		.02	7.1			60
	08-MAR-2012	10:05	0	0		RC.03	7.6	.26	RC13	20
	22-MAR-2012	09:50	0	0		RC.02	7.8			20
	05-APR-2012	09:17	0	0		.02	9.1	.32	14	460
	19-APR-2012	09:53	0	0		.13	11.1			180
Bear Mtn Concession Bldg	11-JAN-2012	11:16			Absent	Absent	.38	6.5		
QC in Meter Box Blue Lid	27-JAN-2012	12:52			Absent	Absent	.48	6.1		
LAN-BM-01	08-FEB-2012	12:35			Absent	Absent	.47	6.8		
	22-FEB-2012	12:56			Absent	Absent	.3	6.4		
	07-MAR-2012	12:50			Absent	Absent	.21	6.6		100
	21-MAR-2012	11:27			Absent	Absent	RC.42	6.6		
	04-APR-2012	12:47			Absent	Absent	.26	7.3		
	18-APR-2012	11:11			Absent	Absent	.16	9.5		640

Station Description Sampling Point Location Code	Date	Time	Total Coliform Limit= 0/100mL CFU or MPN TC	E. coli Limit= 0/100mL CFU or MPN ECOLI	TC Presence Limit = Absent Present/Absent TCPA	Ecoli Presence Limit = Absent Present/Absent ECPA	Chlorine Limit = 3.0 mg/L as Cl2 FCL2T	Water Temp Limit = 15 Degrees C WTEMP	Turbidity Limit = 1 NTU TURB	Colour Limit = 15 TCU COLTR	HPC Count Limit = 10,000 CFU/mL HPC7D
842 Bear Mtn. Parkway	11-JAN-2012	11:58			Absent	Absent	.81	6.8			
QC in Meter Box	27-JAN-2012	13:35			Absent	Absent	.86	6.6			
LAN-BM-03	08-FEB-2012	13:02			Absent	Absent	.78	7.4			
	22-FEB-2012	13:19			Absent	Absent	.59	7.6			
	07-MAR-2012	13:17			Absent	Absent	.3	7.1			
	21-MAR-2012	12:03			Absent	Absent	.81	7.8			
	04-APR-2012	13:10			Absent	Absent	.57	8.3			
	18-APR-2012	11:33			Absent	Absent	.37	9.6			
835 Bear Mtn Pkwy Pumpst	11-JAN-2012	12:04	0	0			1.23	9.7			
Tap on supply main	27-JAN-2012	13:28	0	0			PON 1.13	11.6			
LAN-BM-05	08-FEB-2012	12:57	0	0			PON 1.17	14.8			
	22-FEB-2012	13:11	0	0			RC .57	PON 15.4			
	07-MAR-2012	10:51	0	0			POF .61	14.1			
	21-MAR-2012	11:51	0	0			PON 1.1	12.6			
	04-APR-2012	13:05	0	0			PON .91	15.1			
	18-APR-2012	11:27	0	0			PON .9	15.8			
Hap Val @ Dicker W side	12-JAN-2012	13:16	0	0			1.16	6.8	.29	5.9	
Water + Samp in meter box	26-JAN-2012	08:20	0	0			1.2	5.1			
LAN-HA-01	09-FEB-2012	09:49	0	0			1.3	6.8	.26	6.7	
	23-FEB-2012	07:40	0	0			.98	5.8			
	08-MAR-2012	08:15	0	0			1.03	6.1	.23	4.4	
	22-MAR-2012	08:19	0	0			.84	6.4			
	05-APR-2012	07:29	0	0			RC .6	7.1	.28	5.1	
	19-APR-2012	08:25	0	0			.74	8.1			
Walfred Road Pumpstation	03-JAN-2012	07:40	0	0			PON 1.24	7.1			
Box on outside west wall	16-JAN-2012	12:45	0	0			POF .15	5.6			170
LAN-HA-03	30-JAN-2012	07:45	0	0			PON 1.32	5.7			
	13-FEB-2012	08:35	0	0			PON 1.33	6.1			
	27-FEB-2012	08:30	0	0			PON 1.07	6.3			
	12-MAR-2012	08:28	0	0			PON 1.11	6.8			
	26-MAR-2012	08:35	0	0			POF .72	7.8			
	10-APR-2012	08:37	0	0			PON .77	8.5			
	23-APR-2012	08:40	0	0			PON .98	9.7			

Station Description Sampling Point Location Code	Date	Time	Total Coliform Limit= 0/100mL CFU or MPN TC	E. coli Limit= 0/100mL CFU or MPN ECOLI	TC Presence Limit = Absent Present/Absent TCPA	Ecoli Presence Limit = Absent Present/Absent ECPA	Chlorine Limit = 3.0 mg/L as Cl2 FCL2T	Water Temp Limit = 15 Degrees C WTEMP	Turbidity Limit = 1 NTU TURB	Colour Limit = 15 TCU COLTR	HPC Count Limit = 10,000 CFU/mL HPC7D
Langford Landing, at end QC2 in Meter Box on Right LAN-LL-01	05-JAN-2012	13:12			Absent	Absent	.05	6.7			2450
	18-JAN-2012	:					!SI				
	01-FEB-2012	09:38			Absent	Absent	.04	6.2			260
	15-FEB-2012	09:53			Absent	Absent	.02	6.7			A 1310
	29-FEB-2012	08:49			Absent	Absent	.03	6.7			4120
	14-MAR-2012	09:25			Absent	Absent	.03	7.2			A 9200
	28-MAR-2012	09:06			Absent	Absent	.02	8.1			A 2700
	11-APR-2012	10:03			Absent	Absent	.01	9.1			2440
	25-APR-2012	09:47			Absent	Absent	.06	11.1			A 5500
Gourman@Rason PH red box on wall of PH LAN-TH-01	11-JAN-2012	12:52	0	0			PON 1.4	6.8			
	25-JAN-2012	13:10	0	0			PON 1.2	5.4			
	08-FEB-2012	12:04	0	0			PON 1.25	6.8			
	22-FEB-2012	12:22	0	0			PON .94	7.1			
	07-MAR-2012	12:00	0	0			PON 1.1	6.4			
	21-MAR-2012	10:19	0	0			PON 1.14	6.7			
	04-APR-2012	12:20	0	0			PON 1.28	7.6			
	18-APR-2012	10:35	0	0			PON 1.11	9.1			
1235 Clearwater Place QC-2 in Meter Box on Isl LAN-WE-01	11-JAN-2012	08:25	0	0			1.18	6.6			
	25-JAN-2012	11:40	0	0			1.04	6.6			
	08-FEB-2012	10:16	0	0			1.27	6.8			
	22-FEB-2012	10:25	0	0			1.01	7.2			
	07-MAR-2012	10:23	0	0			.92	7.2			
	21-MAR-2012	13:02	0	0			.63	6.5			
	04-APR-2012	11:11	0	0			.66	8.1			
	18-APR-2012	11:00	0	0			.98	9.8			
Rocky Pt Pumphouse-CRD Red box on east wall MET-ME-02	05-JAN-2012	12:17			Absent	Absent	POF .82	7.3			
	18-JAN-2012	:					!SI				
	01-FEB-2012	13:45			Absent	Absent	PON .94	6.2			
	15-FEB-2012	12:41			Absent	Absent	PON .84	7.1			
	29-FEB-2012	11:28			Absent	Absent	PON .69	6.6			
	14-MAR-2012	12:45			Absent	Absent	PON .8	7.1			
	28-MAR-2012	12:40			Absent	Absent	PON .62	7.8			
	11-APR-2012	13:14			Absent	Absent	PON .44	8.3			
	25-APR-2012	12:38			Absent	Absent	PON .39	10.1			

Station Description Sampling Point Location Code	Date	Time	Total Coliform Limit= 0/100mL CFU or MPN TC	E. coli Limit= 0/100mL CFU or MPN ECOLI	TC Presence Limit = Absent Present/Absent TCPA	Ecoli Presence Limit = Absent Present/Absent ECPA	Chlorine Limit = 3.0 mg/L as Cl2 FCL2T	Water Temp Limit = 15 Degrees C WTEMP	Turbidity Limit = 1 NTU TURB	Colour Limit = 15 TCU COLTR	HPC Count Limit = 10,000 CFU/mL HPC7D
Happy Valley @ Glenforest	12-JAN-2012	13:23	0	0			1.24	6.8			
QC-Mtr box next to hydrnt	26-JAN-2012	08:40	0	0			1.13	5.1			
MET-ME-04	09-FEB-2012	10:02	0	0			1.12	6.6			
	23-FEB-2012	07:50	0	0			.9	5.7			
	08-MAR-2012	08:25	0	0			1.07	5.8			
	22-MAR-2012	08:30	0	0			.84	6.1			
	05-APR-2012	07:41	0	0			RC .35	6.9			
	19-APR-2012	08:38	0	0			.76	7.8			
Meter Box at Aquarius	11-JAN-2012	09:25			Absent	Absent	.27	6.7			
Quik connect @ meter box	08-FEB-2012	11:06	0	0			.29	6.8			
MET-ME-05	07-MAR-2012	11:16	0	0			1.25	6.4			
	21-MAR-2012	:									
	18-APR-2012	11:00			Absent	Absent	1.1	9.1			
909 Arden Rd	05-JAN-2012	12:09			Absent	Absent	.21	7.6			
Quikconnect in meter box	18-JAN-2012	11:53			Absent	Absent	.09	6.2			480
MET-ME-07	01-FEB-2012	13:30			Absent	Absent	1.07	6.6			
	15-FEB-2012	10:20			Absent	Absent	.79	6.8			
	29-FEB-2012	09:24			Absent	Absent	RC .66	6.7			
	14-MAR-2012	12:38			Absent	Absent	.79	6.9			
	28-MAR-2012	12:34			Absent	Absent	.78	7.2			
	11-APR-2012	10:50			Absent	Absent	RC .68	8.2			
	25-APR-2012	12:27			Absent	Absent	.54	10.3			
1010 Rocky Glen Road	12-JAN-2012	13:29	0	0			.06	6.4			100
QC2 in Meter box @ Air/v	26-JAN-2012	08:50	0	0			.1	4.3			60
MET-ME-08	09-FEB-2012	10:11	0	0			.08	6.6			100
	23-FEB-2012	08:02	0	0			.06	6.2			90
	08-MAR-2012	08:35	0	0			.15	6.3			120
	22-MAR-2012	08:45	0	0			.13	6.8			50
	05-APR-2012	07:59	0	0			.16	8.3			A 2500
	19-APR-2012	08:49	0	0			.12	9.9			900

Station Description Sampling Point Location Code	Date	Time	Total Coliform Limit= 0/100mL CFU or MPN TC	E. coli Limit= 0/100mL CFU or MPN ECOLI	TC Presence Limit = Absent Present/Absent TCPA	Ecoli Presence Limit = Absent Present/Absent ECPA	Chlorine Limit = 3.0 mg/L as Cl2 FCL2T	Water Temp Limit = 15 Degrees C WTEMP	Turbidity Limit = 1 NTU TURB	Colour Limit = 15 TCU COLTR	HPC Count Limit = 10,000 CFU/mL HPC7D
E.Sooke Rd @ Rocky Pt Rd	05-JAN-2012	11:25			Absent	Absent	.56	7.6			
QC under metrvault lid	11-JAN-2012	09:10			Absent	Absent	.16	7.1			L 10
MET-PB-01	18-JAN-2012	:					!SI				
	25-JAN-2012	10:10			Absent	Absent	1.72	6.1			
	01-FEB-2012	13:19			Absent	Absent	1.38	6.4			
	08-FEB-2012	10:50			Absent	Absent	1.07	7			
	15-FEB-2012	11:10			Absent	Absent	1.04	7.2			
	22-FEB-2012	11:01			Absent	Absent	1.3	7.2			
	29-FEB-2012	10:00			Absent	Absent	1.17	7.1			
	07-MAR-2012	11:30			Absent	Absent	1.27	7.1			
	14-MAR-2012	11:16			Absent	Absent	1.06	7			
	21-MAR-2012	13:33			Absent	Absent	1.32	7.3			
	28-MAR-2012	11:55			Absent	Absent	1.22	7.9			
	04-APR-2012	11:35			Absent	Absent	1.14	8			
	11-APR-2012	11:32			Absent	Absent	1.02	8.1			
	18-APR-2012	09:37			Absent	Absent	.96	8.6			
	25-APR-2012	11:42			Absent	Absent	.91	9.7			
Meter Vault-W.Hd. Prison	05-JAN-2012	12:33			Absent	Absent	.61	7.8	.28		
tap in meter vault bldg	18-JAN-2012	13:29			Absent	Absent	.7	6.2			
MET-WH-02	01-FEB-2012	09:38			Absent	Absent	.63	7	.25		
	15-FEB-2012	13:13			Absent	Absent	.59	7.3			
	29-FEB-2012	11:42			Absent	Absent	.52	7.3	.26		
	14-MAR-2012	12:58			Absent	Absent	.6	7.3			
	28-MAR-2012	13:08			Absent	Absent	.43	8.1	.41		
	11-APR-2012	13:28			Absent	Absent	.43	9.2			
	25-APR-2012	12:51			Absent	Absent	.36	10.3	.27		
Pearson College Rd	27-JAN-2012	13:59	0	0			.78	7.3			
QC under vault lid	15-FEB-2012	12:58	0	0			.86	7.1			
MET-WH-09	21-MAR-2012	:									
	28-MAR-2012	12:56	0	0			.42	7.9			
	25-APR-2012	12:45	0	0			.71	10.4			

Station Description	Date	Time	Total Coliform Limit= 0/100mL CFU or MPN TC	E. coli Limit= 0/100mL CFU or MPN ECOLI	TC Presence Limit = Absent Present/Absent TCPA	Ecoli Presence Limit = Absent Present/Absent ECPA	Chlorine Limit = 3.0 mg/L as Cl2 FCL2T	Water Temp Limit = 15 Degrees C WTEMP	Turbidity Limit = 1 NTU TURB	Colour Limit = 15 TCU COLTR	HPC Count Limit = 10,000 CFU/mL HPC7D
Vic General Hosp(#1main)	13-JAN-2012	14:12			Absent	Absent	1.35	5.1	.31		
tap in can at Hos turnab	27-JAN-2012	07:20			Absent	Absent	RC 1.44	4.6	.28		
VIR-HO-03	10-FEB-2012	09:49			Absent	Absent	1.4	6.8	.38		
	24-FEB-2012	07:25			Absent	Absent	1.06	5.3	.48		
	09-MAR-2012	08:30			Absent	Absent	1.21	5.3	.28		
	23-MAR-2012	08:15			Absent	Absent	1.03	5.3	.34		
	05-APR-2012	13:21			Absent	Absent	.26	6.7	.4		
	20-APR-2012	08:29			Absent	Absent	1.03	7.2	.33		
Grand Totals											
Overall Statistics	03-JAN-2012	Samples	79	79	76	76	155	155	21	8	29
for Location Class	to	Mean	0	0	0	0	.74	7.55	.31	9.89	1208.97
R9M	25-APR-2012	Minimum	0	0	0	0	0	4.3	.23	4.4	0
WESTSHORE. DISTRIBUTION SYSTE		Maximum	0	0	0	0	1.72	15.8	.48	16	9200
		Median	0	0	0	0	.8	7.1	.28	9.85	180
		Percent Positive	0.0%	0.0%							

End of Report: BACTXLC8