

Report to			Remark Codes								
			!SI		Point Inaccessible						
			RC		Reconfirmed						
			RES		Resample;Special						
Station Description			Total Coliform	E. coli	TC Presence	Ecoli Presence	Chlorine	Water Temp	Turbidity	Colour	HPC Count
Sampling Point			Limit= 0/100mL	Limit= 0/100mL	Limit = Absent	Limit = Absent	Limit = 3.0	Limit = 15	Limit = 1	Limit = 15	Limit = 10,000
Location Code			CFU or MPN	CFU or MPN	Present/Absent	Present/Absent	mg/L as Cl2	Degrees C	NTU	TCU	CFU/mL
Date	Time		TC	ECOLI	TCPA	ECPA	FCL2T	WTEMP	TURB	COLTR	HPC7D
2159 Mt. Newton Cross Rd	11-JAN-2012	14:15	0	0			1.25	7.8	RC.74		
QC in meter box in dway	19-JAN-2012	12:53					ISI				
CES-SA-04	25-JAN-2012	13:45	0	0			1.16	6.1	.26		
	08-FEB-2012	14:00	0	0			1.15	6.6	RC.93		
	22-FEB-2012	13:09	0	0			.7	7.1	.37		
	07-MAR-2012	12:50	0	0			.64	6.4	.24		
	21-MAR-2012	12:35	0	0			.93	7.1	.28		
	04-APR-2012	13:03	0	0			1	7.6	.28		
	18-APR-2012	12:49	0	0			.93	9.3	.37		
Gorge Hosp @ Lotus&Irma	09-JAN-2012	09:20	0	0			1.05	7.6	.28	6.3	
QC under lid on island	23-JAN-2012	09:30	0	0			1.02	6.2	.3	5.9	
VIC-BU-03	06-FEB-2012	10:33	0	0			.91	7	.29	5.6	
	20-FEB-2012	08:30	0	0			.81	6.9	.29	4.9	
	05-MAR-2012	08:50	0	0			.66	7.4	.3	4.7	
	19-MAR-2012	08:59	0	0			.66	8.1	.28	5.1	
	02-APR-2012	08:51	0	0			.84	8.8	.39	4.4	
	16-APR-2012	09:00	0	0			.62	10.6	.25	4.1	
	30-APR-2012	08:52	0	0			.78	11.6	.24	4.8	
R. Jubilee Hosp Powerhse	09-JAN-2012	09:50			Absent	Absent	1.37	7.3	.38		
Tap on wmain inside bldg	23-JAN-2012	09:50			Absent	Absent	1.33	5.4	.33	5.9	
VIC-FE-02	06-FEB-2012	10:56			Absent	Absent	1.27	5.7	.34		
	20-FEB-2012	08:59			Absent	Absent	1.19	5.6	.46		
	05-MAR-2012	09:15			Absent	Absent	RC1.09	6.2	.51		
	19-MAR-2012	09:28			Absent	Absent	1.04	6.5	.61		
	02-APR-2012	09:17			Absent	Absent	1.02	6.8	RC1.65		
	03-APR-2012	12:04					.94	7	RES.44		
	16-APR-2012	09:35			Absent	Absent	1.06	7.8	.31		
	30-APR-2012	09:19			Absent	Absent	1.09	8.9	.49		

Station Description Sampling Point Location Code	Date	Time	Total Coliform Limit= 0/100mL CFU or MPN TC	E. coli Limit= 0/100mL CFU or MPN ECOLI	TC Presence Limit = Absent Present/Absent TCPA	Ecoli Presence Limit = Absent Present/Absent ECPA	Chlorine Limit = 3.0 mg/L as Cl2 FCL2T	Water Temp Limit = 15 Degrees C WTEMP	Turbidity Limit = 1 NTU TURB	Colour Limit = 15 TCU COLTR	HPC Count Limit = 10,000 CFU/mL HPC7D
Vic General Hosp(#1main)	13-JAN-2012	14:12			Absent	Absent	1.35	5.1	.31		
tap in can at Hos turnab	27-JAN-2012	07:20			Absent	Absent	RC 1.44	4.6	.28		
VIR-HO-03	10-FEB-2012	09:49			Absent	Absent	1.4	6.8	.38		
	24-FEB-2012	07:25			Absent	Absent	1.06	5.3	.48		
	09-MAR-2012	08:30			Absent	Absent	1.21	5.3	.28		
	23-MAR-2012	08:15			Absent	Absent	1.03	5.3	.34		
	05-APR-2012	13:21			Absent	Absent	.26	6.7	.4		
	20-APR-2012	08:29			Absent	Absent	1.03	7.2	.33		
Grand Totals			Total Coliform Limit= 0/100mL CFU or MPN TC	E. coli Limit= 0/100mL CFU or MPN ECOLI	TC Presence Limit = Absent Present/Absent TCPA	Ecoli Presence Limit = Absent Present/Absent ECPA	Chlorine Limit = 3.0 mg/L as Cl2 FCL2T	Water Temp Limit = 15 Degrees C WTEMP	Turbidity Limit = 1 NTU TURB	Colour Limit = 15 TCU COLTR	HPC Count Limit = 10,000 CFU/mL HPC7D
Overall Statistics	09-JAN-2012	Samples	17	17	17	17	35	35	35	10	0
for Location Class	to	Mean	0	0	0	0	1.01	7.02	.41	5.17	
RHOSP	30-APR-2012	Minimum	0	0	0	0	.26	4.6	.24	4.1	
GREATER VICTORIA HOSPITALS-SUP		Maximum	0	0	0	0	1.44	11.6	1.65	6.3	
		Median	0	0	0	0	1.03	6.9	.33	5	
		Percent Positive	0.0%	0.0%							

End of Report: BACTXLC8