

Inquiries at: 474-9680

Location Class:

R9M

WESTSHORE. DISTRIBUTION SYSTEM

Reporting Period: 01-APR-2012 to 30-APR-2012

Station Description Sampling Point Location Code	Date	Time	Total Coliform Limit= 0/100mL CFU or MPN TC	E. coli Limit= 0/100mL CFU or MPN ECOLI	TC Presence Limit = Absent Present/Absent TCPA	Ecoli Presence Limit = Absent Present/Absent ECPA	Chlorine Limit = 3.0 mg/L as Cl2 FCL2T	Water Temp Limit = 15 Degrees C WTEMP	Turbidity Limit = 1 NTU TURB	Colour Limit = 15 TCU COLTR	HPC Count Limit = 10,000 CFU/mL HPC7D
Gourman@Rason PH red box on wall of PH LAN-TH-01	04-APR-2012	12:20	0	0			PON 1.28	7.6			
	18-APR-2012	10:35	0	0			PON 1.11	9.1			
1235 Clearwater Place QC-2 in Meter Box on Isl LAN-WE-01	04-APR-2012	11:11	0	0			.66	8.1			
	18-APR-2012	11:00	0	0			.98	9.8			
Rocky Pt Pumphouse-CRD Red box on east wall MET-ME-02	11-APR-2012	13:14			Absent	Absent	PON .44	8.3			
	25-APR-2012	12:38			Absent	Absent	PON .39	10.1			
Happy Valley @ Glenforest QC-Mtr box next to hydrnt MET-ME-04	05-APR-2012	07:41	0	0			RC .35	6.9			
	19-APR-2012	08:38	0	0			.76	7.8			
Meter Box at Aquarius Quik connect @ meter box MET-ME-05	18-APR-2012	11:00			Absent	Absent	1.1	9.1			
909 Arden Rd Quikconnect in meter box MET-ME-07	11-APR-2012	10:50			Absent	Absent	RC .68	8.2			
	25-APR-2012	12:27			Absent	Absent	.54	10.3			
1010 Rocky Glen Road QC2 in Meter box @ Air/v MET-ME-08	05-APR-2012	07:59	0	0			.16	8.3			A 2500
	19-APR-2012	08:49	0	0			.12	9.9			900
E.Sooke Rd @ Rocky Pt Rd QC under metrvault lid MET-PB-01	04-APR-2012	11:35			Absent	Absent	1.14	8			
	11-APR-2012	11:32			Absent	Absent	1.02	8.1			
	18-APR-2012	09:37			Absent	Absent	.96	8.6			
	25-APR-2012	11:42			Absent	Absent	.91	9.7			
Meter Vault-W.Hd. Prison tap in meter vault bldg MET-WH-02	11-APR-2012	13:28			Absent	Absent	.43	9.2			
	25-APR-2012	12:51			Absent	Absent	.36	10.3	.27		

Station Description Sampling Point Location Code	Date	Time	Total Coliform Limit= 0/100mL CFU or MPN TC	E. coli Limit= 0/100mL CFU or MPN ECOLI	TC Presence Limit = Absent Present/Absent TCPA	Ecoli Presence Limit = Absent Present/Absent ECPA	Chlorine Limit = 3.0 mg/L as Cl2 FCL2T	Water Temp Limit = 15 Degrees C WTEMP	Turbidity Limit = 1 NTU TURB	Colour Limit = 15 TCU COLTR	HPC Count Limit = 10,000 CFU/mL HPC7D
Pearson College Rd QC under vault lid MET-WH-09	25-APR-2012	12:45	0	0			.71	10.4			
Vic General Hosp(#1main) tap in can at Hos turnab VIR-HO-03	05-APR-2012	13:21			Absent	Absent	.26	6.7	.4		
	20-APR-2012	08:29			Absent	Absent	1.03	7.2	.33		

End of Report: BACTXLC8