

Report to			Remark Codes							
			RC	Reconfirmed						
			RES	Resample;Special						
Station Description	Total Coliform	E. coli	TC Presence	Ecoli Presence	Chlorine	Water Temp	Turbidity	Colour	HPC Count	
Sampling Point	Limit= 0/100mL	Limit= 0/100mL	Limit = Absent	Limit = Absent	Limit = 3.0	Limit = 15	Limit = 1	Limit = 15	Limit = 10,000	
Location Code	CFU or MPN	CFU or MPN	Present/Absent	Present/Absent	mg/L as Cl2	Degrees C	NTU	TCU	CFU/mL	
Date	Time	TC	ECOLI	TCPA	ECPA	FCL2T	WTEMP	TURB	COLTR	HPC7D
2159 Mt. Newton Cross Rd	04-APR-2012	13:03	0	0		1	7.6	.28		
QC in meter box in dway	18-APR-2012	12:49	0	0		.93	9.3	.37		
CES-SA-04										
Gorge Hosp @ Lotus&Irma	02-APR-2012	08:51	0	0		.84	8.8	.39	4.4	
QC under lid on island	16-APR-2012	09:00	0	0		.62	10.6	.25	4.1	
VIC-BU-03	30-APR-2012	08:52	0	0		.78	11.6	.24	4.8	
R. Jubilee Hosp Powerhse	02-APR-2012	09:17			Absent	Absent	1.02	6.8		RC1.65
Tap on wmain inside bldg	03-APR-2012	12:04					.94	7		RES.44
VIC-FE-02	16-APR-2012	09:35			Absent	Absent	1.06	7.8		.31
	30-APR-2012	09:19			Absent	Absent	1.09	8.9		.49
Vic General Hosp(#1 main)	05-APR-2012	13:21			Absent	Absent	.26	6.7		.4
tap in can at Hos turnab	20-APR-2012	08:29			Absent	Absent	1.03	7.2		.33
VIR-HO-03										

End of Report: BACTXLC8