

Report to			Remark Codes							
			POF		Pump OFF(sampl.pt)					
			RC		Reconfirmed					
			RES		Resample;Special					
Station Description	Total Coliform	E. coli	TC Presence	Ecoli Presence	Chlorine	Water Temp	Turbidity	Colour	HPC Count	
Sampling Point	Limit= 0/100mL	Limit= 0/100mL	Limit = Absent	Limit = Absent	Limit = 3.0	Limit = 15	Limit = 1	Limit = 15	Limit = 10,000	
Location Code	CFU or MPN	CFU or MPN	Present/Absent	Present/Absent	mg/L as Cl2	Degrees C	NTU	TCU	CFU/mL	
Date	Time	TC	ECOLI	TCPA	ECPA	FCL2T	WTEMP	TURB	COLTR	HPC7D
Admirals meter vault	12-APR-2012	08:00		Absent	Absent	.76	8.2			
red bx,outside wall	25-APR-2012	08:32		Absent	Absent	.84	9			
ESQ-ES-02										
#1 Mn @ Glen Lake School	02-APR-2012	08:11		Absent	Absent	1.06	5.7			
Sample Box on Vault	10-APR-2012	08:29		Absent	Absent	.73	6.6			
KHB-03-36	16-APR-2012	08:27		Absent	Absent	.81	6.2			
	23-APR-2012	08:25		Absent	Absent	1.14	7.6			
	30-APR-2012	08:09		Absent	Absent	1.34	7.3			
39" Main @ Glen Lk Sch.	02-APR-2012	08:01	0			1.1	5.7	.37	4.2	
Continuous Flow Stn.	10-APR-2012	08:15	0			.57	6.8			
KHB-03-39	16-APR-2012	08:20	0			.6	6.5			
	23-APR-2012	08:17	0			1.16	7.6			
	30-APR-2012	07:58	0			1.17	7.5	.32	4.5	
Deep Cove Pump inlet	04-APR-2012	12:27	0			POF .96	8.6			
Tap under u/s hatch	18-APR-2012	12:11	0			POF .9	8.7			
NOS-DC-02	24-APR-2012	11:54				.83	9.5			
Lansdowne & Foul Bay Rd	03-APR-2012	12:43		Absent	Absent	.97	6.5			
brown sample tap enclosure	11-APR-2012	12:09		Absent	Absent	.8	7.2			
OAB-HE-01	17-APR-2012	12:43		Absent	Absent	.96	7.4			
	24-APR-2012	12:27		Absent	Absent	1.07	8.4			
Markham meter vault	11-APR-2012	12:41	1			1.09	7.9			
red box on front of bldg	12-APR-2012	13:10	RES0			1.08	8.2			
SAN-BL-01	24-APR-2012	12:59	0			.96	9.8			
Dooley meter vault	02-APR-2012	10:47	0			1.15	6.1	.29	4.8	
red box	10-APR-2012	11:19	0			1.13	6.8	.31	4.4	
SAN-CB-02	16-APR-2012	11:11	0			1.17	6.8	.34	4.3	
	23-APR-2012	11:29	0			1.12	7.7	.39	4.8	
	30-APR-2012	10:53	0			1.12	8.1	.31	3.8	

Station Description Sampling Point Location Code	Date	Time	Total Coliform Limit= 0/100mL CFU or MPN TC	E. coli Limit= 0/100mL CFU or MPN ECOLI	TC Presence Limit = Absent Present/Absent TCPA	Ecoli Presence Limit = Absent Present/Absent ECPA	Chlorine Limit = 3.0 mg/L as Cl2 FCL2T	Water Temp Limit = 15 Degrees C WTEMP	Turbidity Limit = 1 NTU TURB	Colour Limit = 15 TCU COLTR	HPC Count Limit = 10,000 CFU/mL HPC7D
Mt Tolmie Res Supply 3MN Red box sampling station SAN-MT-01	02-APR-2012	09:35	0	0			.74	7.6			
	16-APR-2012	09:45	0	0			RC .71	8.6			
	30-APR-2012	09:41	0	0			1.04	8.6			
Cecelia Meter Vault red box side of bldg VIC-BU-01	11-APR-2012	11:15	0	0			.73	7.9			
	24-APR-2012	11:36	0	0			.82	9.3			
Craigflower meter vault gray box near door VIC-GL-01	10-APR-2012	09:20	0	0			1	6.8			
	23-APR-2012	09:29	0	0			1.07	8			
Fountain Circle PRV Black box N wall Muffler shop VIC-HI-02	03-APR-2012	12:24			Absent	Absent	.97	6.8			
	17-APR-2012	12:23	0	0			.97	7.6			
Cook & Mallek meter vault Sample tap inside door VIC-MA-01	05-APR-2012	11:45			Absent	Absent	.95	6.3			
	19-APR-2012	10:26			Absent	Absent	1.11	7.2			
Tyee @ Bay PRV vault QConnect under hatch VIC-VW-01	12-APR-2012	08:37			Absent	Absent	.87	7.2			
	25-APR-2012	08:50			Absent	Absent	.96	8.2			

End of Report: BACTXLC8