

2012 Bacteriological Summary

Location Class: R8 D/S RESERVOIRS (includes Sooke)

Location Class	Month	Bacterial Water Samples Collected	Total Coliforms				E.coli Samples > 0 CFU/100mL	Fecal Coliforms Samples FC > 0 CFU/100mL	Turbidity		Chlorine Residual Monthly Median mg/L as Cl2	Water Temperature Monthly Median Degrees C.
			Samples TC > 0 CFU/100mL	TC > 0 Percent	Resamples TC > 0 CFU/100mL	Samples TC > 10 CFU/100mL			Samples Adverse > 1 NTU			
D/S RESERVOIRS (includes Sooke) R8	JAN	75	1	1.3%	0	0	0	3	0	.65	5.8	
	FEB	80	0	.0%	0	0	0	5	0	.70	6.1	
	MAR	76	0	.0%	0	0	0	3	0	.58	6.2	
	APR	77	0	.0%	0	0	0	4	0	.45	8.2	
	Totals	308	1	.3%	0	0	0	15	0	.58	6.4	

NOTES: > = Greater than, TC = Total Coliforms, FC = Fecal Coliforms, TCBK = Background colonies on a Total Coliform membrane filter, CFU = Colony Forming Units

COMMENTS: