

2012 Bacteriological Summary

Location Class: RHOSP GREATER VICTORIA HOSPITALS-SUPPLY

Location Class	Month	Bacterial Water Samples Collected	Total Coliforms				E.coli Samples > 0 CFU/100mL	Fecal Coliforms Samples FC > 0 CFU/100mL	Turbidity		Chlorine Residual Monthly Median mg/L as Cl2	Water Temperature Monthly Median Degrees C.
			Samples TC > 0 CFU/100mL	TC > 0 Percent	Resamples TC > 0 CFU/100mL	Samples TC > 10 CFU/100mL			Samples Adverse > 1 NTU			
GREATER VICTORIA HOSPITALS-SUPPLY	JAN	8	0	.0%	0	0	0	8	0	1.29	6.2	
RHOSP	FEB	8	0	.0%	0	0	0	8	0	1.11	6.7	
	MAR	8	0	.0%	0	0	0	8	0	.98	6.5	
	APR	10	0	.0%	0	0	0	11	1	.94	7.8	
	Totals	34	0	.0%	0	0	0	35	1	1.03	7.0	

NOTES: > = Greater than, TC = Total Coliforms, FC = Fecal Coliforms, TCBK = Background colonies on a Total Coliform membrane filter, CFU = Colony Forming Units

COMMENTS: