

2011 Bacteriological Summary

Location Class: RHOSP GREATER VICTORIA HOSPITALS-SUPPLY

Location Class	Month	Bacterial Water Samples Collected	Total Coliforms				E.coli Samples > 0 CFU/100mL	Fecal Coliforms Samples FC > 0 CFU/100mL	Turbidity		Chlorine Residual Monthly Median mg/L as Cl2	Water Temperature Monthly Median Degrees C.
			Samples TC > 0 CFU/100mL	TC > 0 Percent	Resamples TC > 0 CFU/100mL	Samples TC > 10 CFU/100mL			Samples Collected	Adverse > 1 NTU		
GREATER VICTORIA HOSPITALS-SUPPLY RHOSP	JAN	8	0	.0%	0	0	0	8	0	.99	6.4	
	FEB	7	0	.0%	0	0	0	7	0	.83	6.9	
	MAR	8	0	.0%	0	0	0	8	0	.95	6.4	
	APR	8	0	.0%	0	0	0	7	0	.94	8.2	
	MAY	10	0	.0%	0	0	0	10	0	.87	10.4	
	JUN	10	1	10.0%	0	0	0	10	0	1.18	13.1	
	JUL	10	2	20.0%	0	0	0	8	0	1.10	16.5	
	AUG	8	0	.0%	0	0	0	8	0	1.01	17.9	
	SEP	8	0	.0%	0	0	0	8	0	.91	18.6	
	OCT	9	1	11.1%	0	0	0	8	0	.79	15.0	
	NOV	12	0	.0%	0	0	0	11	0	1.26	10.3	
	DEC	9	0	.0%	0	0	0	9	0	1.31	7.5	
	Totals	107	4	3.7%	0	0	0	102	0	1.06	10.7	

NOTES: > = Greater than, TC = Total Coliforms, FC = Fecal Coliforms, TCBK = Background colonies on a Total Coliform membrane filter, CFU = Colony Forming Units

COMMENTS: