

CAPITAL REGIONAL DISTRICT - INTEGRATED WATER SERVICES
Water Watch for Dec 04, 2011

Water Supply System Summary:**1. Useable Volume in Storage:**

| Reservoir | December 31 5 Year Ave | | December 31/10 | | December 4/11 | | % Existing Full Storage |
|------------|---------------------------|--------|----------------|--------|---------------|--------|----------------------------|
| | ML | MIG | ML | MIG | ML | MIG | |
| Sooke | 84,144 | 18,512 | 92,727 | 20,400 | 76,478 | 16,825 | 82.5% |
| Goldstream | 9,259 | 2,037 | 9,825 | 2,162 | 7,901 | 1,738 | 80.4% |
| Total | 93,403 | 20,549 | 102,552 | 22,561 | 84,379 | 18,563 | 82.3% |

2. Average Daily Demand:

| | | |
|-----------------------------------|----------|-----------|
| For the month of December | 103.3 ML | 22.73 MIG |
| For week ending December 04, 2011 | 103.4 ML | 22.75 MIG |
| Max. day December 2011, to date: | 104.9 ML | 23.07 MIG |

3. Average 5 Year Daily Demand for December

| | | |
|-----------------------|------------------------|-------------------------|
| Average (2006 - 2010) | 111.3 MLD ¹ | 24.47 MIGD ² |
|-----------------------|------------------------|-------------------------|

¹MLD = Million Litres Per Day ²MIGD = Million Imperial Gallons Per Day

4. Rainfall December:

| | |
|-------------------------|-----------------------------|
| Average (1914 - 2010): | 297.6 mm |
| Actual Rainfall to Date | 0.0 (0% of monthly average) |

5. Rainfall: Sep 1 - Dec 4

| | |
|----------------------|------------------------|
| Average (1914-2010): | 533.0 mm |
| 2011 | 476.9 (89% of average) |

6. Water Conservation Action Required:

To avoid possible leaks next spring, now is the time to winterize your sprinkler system.

Check our website at www.crd.bc.ca/water for more information.

If you require further information, please contact:

J.A. (Jack) Hull, MBA, P. Eng.
 General Manager, CRD - Integrated Water Services
 or

Deborah Walker
 Demand Management Coordinator

Capital Regional District Integrated Water Services
 479 Island Highway
 Victoria, BC V9B 1H7
 (250) 474-9600