

**CAPITAL REGIONAL DISTRICT - INTEGRATED WATER SERVICES**  
Water Watch for May 1, 2011

**Water Supply System Summary:****1. Useable Volume in Storage:**

Reservoir	May 31 5 Year Ave		May 31/10		May 1/11		% Existing Full Storage
	ML	MIG	ML	MIG	ML	MIG	
Sooke	86,518	19,034	91,720	20,178	92,727	20,400	100%
Goldstream	9,509	2,092	9,775	2,151	9,824	2,161	100%
Total	96,027	21,126	101,495	22,329	102,552	22,561	100%

**2. Average Daily Demand:**

For the month of May	119.8 ML	26.35 MIG
For week ending May 01, 2011	112.2 ML	24.68 MIG
Max. day May 2011, to date:	119.8 ML	26.35 MIG

**3. Average 5 Year Daily Demand for May**

Average (2006 - 2010)	157.0 MLD <sup>1</sup>	34.52 MIGD <sup>2</sup>
-----------------------	------------------------	-------------------------

<sup>1</sup>MLD = Million Litres Per Day      <sup>2</sup>MIGD = Million Imperial Gallons Per Day

**4. Rainfall May:**

Average (1914 - 2010):	48.4 mm
Actual Rainfall to Date	0.0 (0% of monthly average)

**5. Rainfall: Sep 1 - May 1**

Average (1914-2010):	1504.6 mm
2010 /2011:	1681.9 (112% of average)

**6. Water Conservation Action Required:**

Stage one of the water conservation bylaw is now in effect.  
 Check our website at [www.crd.bc.ca/water](http://www.crd.bc.ca/water) for more information.  
 If you require further information, please contact:

J.A. (Jack) Hull, MBA, P. Eng.  
 General Manager, CRD - Integrated Water Services  
 or  
 Deborah Walker  
 Demand Management Coordinator

Capital Regional District Integrated Water Services  
 479 Island Highway  
 Victoria, BC V9B 1H7  
 (250) 474-9600