

CAPITAL REGIONAL DISTRICT - INTEGRATED WATER SERVICES
Water Watch for Oct. 16, 2011

Water Supply System Summary:**1. Useable Volume in Storage:**

Reservoir	October 31 5 Year Ave		October 31/10		October 16/11		% Existing Full Storage
	ML	MIG	ML	MIG	ML	MIG	
Sooke	57,607	12,674	69,153	15,214	67,676	14,889	73.0%
Goldstream	6,825	1,501	7,671	1,688	6,812	1,499	69.3%
Total	64,432	14,175	76,824	16,901	74,488	16,387	72.6%

2. Average Daily Demand:

For the month of October	115.7 ML	25.46 MIG
For week ending October 16, 2011	112.0 ML	24.64 MIG
Max. day October 2011, to date:	129.3 ML	28.46 MIG

3. Average 5 Year Daily Demand for October

Average (2006 - 2010)	124.2 MLD ¹	27.32 MIGD ²
-----------------------	------------------------	-------------------------

¹MLD = Million Litres Per Day ²MIGD = Million Imperial Gallons Per Day

4. Rainfall October:

Average (1914 - 2010):	168.3 mm
Actual Rainfall to Date	58.0 (34% of monthly average)

5. Rainfall: Sep 1 - Oct 16

Average (1914-2010):	133.8 mm
2011	153.6 (115% of average)

6. Water Conservation Action Required:

To avoid possible leaks next spring, now is the time to winterize your sprinkler system.

Check our website at www.crd.bc.ca/water for more information.

If you require further information, please contact:

J.A. (Jack) Hull, MBA, P. Eng.
 General Manager, CRD - Integrated Water Services
 or
 Deborah Walker
 Demand Management Coordinator

Capital Regional District Integrated Water Services
 479 Island Highway
 Victoria, BC V9B 1H7
 (250) 474-9600

Please note that a recently installed rain gauge at Sooke Dam wasn't calibrated properly from the factory, and resulted in erroneous readings from September 21, 2011. This has now been corrected.