

CAPITAL REGIONAL DISTRICT - INTEGRATED WATER SERVICES
Water Watch for Sept.25, 2011

Water Supply System Summary:**1. Useable Volume in Storage:**

Reservoir	September 30 5 Year Ave		September 30/10		September 25/11		% Existing Full Storage
	ML	MIG	ML	MIG	ML	MIG	
Sooke	59,656	13,124	68,884	15,154	69,086	15,199	74.5%
Goldstream	7,594	1,671	8,093	1,780	7,337	1,614	74.7%
Total	67,250	14,795	76,977	16,935	76,423	16,813	74.5%

2. Average Daily Demand:

For the month of September	177.2 ML	38.97 MIG
For week ending September 25, 2011	147.1 ML	32.36 MIG
Max. day September 2011, to date:	219.4 ML	48.26 MIG

3. Average 5 Year Daily Demand for September

Average (2006 - 2010)	162.9 MLD ¹	35.84 MIGD ²
-----------------------	------------------------	-------------------------

¹MLD = Million Litres Per Day ²MIGD = Million Imperial Gallons Per Day

4. Rainfall September:

Average (1914 - 2010):	63.0 mm
Actual Rainfall to Date	52.5 (83% of monthly average)

5. Rainfall: Sep 1 - Sep 25

Average (1914-2010):	48.0 mm
2011	52.5 (109% of average)

6. Water Conservation Action Required:

Stage one of the water conservation bylaw is now in effect.

Check our website at www.crd.bc.ca/water for more information.

If you require further information, please contact:

J.A. (Jack) Hull, MBA, P. Eng.
 General Manager, CRD - Integrated Water Services
 or
 Deborah Walker
 Demand Management Coordinator

Capital Regional District Integrated Water Services
 479 Island Highway
 Victoria, BC V9B 1H7
 (250) 474-9600