

# Wastewater Treatment

## BIOSOLIDS PRODUCTION REPORT

Capital Regional District | September 2023

### Summary of Biosolids Production & End Use

#### 1. Amount of Biosolids Produced

In September, 33 tonnes (t) of Class A biosolids produced at the Residuals Treatment Facility (RTF) were used as alternative fuel in a cement kiln in Richmond BC, per the Definitive Plan. 100 t of biosolids were mixed with sand and provided to a gravel quarry in Cassidy, BC for future use as biosolids growing media in quarry reclamation.

During September, the RTF's dryer stopped functioning, resulting in the need to dispose of 272 t of Non-Class A Biosolids (25% solids) at Hartland Landfill as controlled waste. For comparison, 272 t of Non-Class A Biosolids are equivalent to 68 t of Class A biosolids and represent about 7 days of production.

Information on the CRD's biosolids beneficial use strategy can be found [here](#). The Definitive Plan can be found [here](#) and the Contingency Plan can be found [here](#).

Biosolids production and end use data for September 2023 is as follows:

Biosolids Type	Produced		End Use		
			Definitive Plan <sup>b</sup>	Alternative Contingency Plan <sup>c</sup>	Hartland Landfill <sup>d</sup>
Dried <sup>a</sup> Class A	This month	133 t	33 t	100 t	0 t
	Year to date	2,001 t	55 t	391 t	1,555 t
Non-Class A	This month	272 t			272 t
	Year to date	555 t			555 t

<sup>a</sup> Greater than 90% solids

<sup>b</sup> Used as an alternative fuel at the Lafarge cement manufacturing facility in Richmond, BC

<sup>c</sup> Mixed with sand at Hartland Landfill and stockpiled in Cassidy for future use in site reclamation

<sup>d</sup> Class A Biosolids are rendered inert by mixing with soil and landfilled within leachate containment areas, and Non-Class A Biosolids are landfilled as a controlled waste

# Wastewater Treatment

## BIOSOLIDS PRODUCTION REPORT

Capital Regional District | September 2023

### 2. Compliance Monitoring

The CRD's contractor, Hartland Resource Management Group (HRMG), tests biosolids produced at the RTF to ensure the biosolids are Class A, as defined by the British Columbia Organic Matter Recycling Regulation (OMRR). Testing is performed by CARO Analytical Services. OMRR specifies that for Class A biosolids, metals concentrations must not exceed "those specified in Trade Memorandum T-4-93 (September 1997), Standards for Metals in Fertilizers and Supplements, as amended from time to time." The latest version of OMRR can be found [here](#) and the latest version of Trade Memorandum T-4-93 can be found [here](#). In June 2022, The Ministry of Environment and Climate Change Strategy announced the intention to amend OMRR, including new standards for Class A biosolids. Regulatory amendments are targeted for 2023. The proposed OMRR Standards have been included in the table for reference.

Class A biosolids compliance data for September 2023 is as follows:

Substance	OMRR Standard <sup>a</sup> (mg/kg dry weight)	Proposed OMRR Standard <sup>b</sup> (mg/kg dry weight)	Biosolids Concentration <sup>c</sup> (mg/kg dry weight)
<b>Metals</b>			
Arsenic (As)	666	41	1.98
Cadmium (Cd)	177	15	1.59
Chromium (Cr)	9,333	1000	40.6
Cobalt (Co)	1,333	150	2.66
Copper (Cu)	6,666	1500	561
Mercury (Hg)	44	4	0.803
Molybdenum (Mo)	177	20	9.16
Nickel (Ni)	1,600	180	17.9
Lead (Pb)	4,444	300	36.4
Selenium (Se)	124	25	6.04
Thallium (Tl)	44	ns	<0.10
Vanadium (V)	5,777	ns	12.6
Zinc (Zn)	16,444	1820	1080
<b>Fecal Coliforms</b>			
MPN	1,000	1000	3.7

<sup>a</sup> For metals, the maximum allowable concentrations for Class A biosolids are calculated based on a 500 kg/ha annual application rate; for fecal coliforms, the maximum allowable concentration is a fixed value

# Wastewater Treatment

## BIOSOLIDS PRODUCTION REPORT

Capital Regional District | September 2023

<sup>b</sup> Proposed OMRR standards are tabled for reference - standards subject to change once final OMRR amendment is published.

<sup>c</sup> Results based on single sample due to low volume of Class A biosolids produced.

ns – no standard