

GANGES SEWER LOCAL SERVICES COMMISSION

Notice of Special Meeting on **THURSDAY**, **January 8**, **2015 at 1:00 pm** Salt Spring Public Library, 129 McPhillips Avenue, Salt Spring Island, BC

Wayne McIntyre John Sprague Kevin Bell Gary Utter Rod Scotvold

Louis Pepin

AGENDA

- 1. Approval of Agenda
- 2. Reports
 - 2.1 Sludge Disposal Options for Ganges Sewer Project
 - 2.2 Ganges Sewer Infrastructure Replacement Project-Results of the Public Open House Meeting
- 3. New Business
- 4. Outstanding Business
- 5. Adjournment



REPORT TO GANGES SEWER LOCAL SERVICE COMMISSION MEETING OF THURSDAY, JANUARY 8, 2015

SUBJECT SLUDGE DISPOSAL OPTIONS FOR GANGES SEWER PROJECT

ISSUE

To review alternative options for sludge disposal for the Ganges Sewer Project to determine the lowest cost option from a lifecycle perspective.

BACKGROUND

Currently, the wastewater entering the Ganges Wastewater Treatment Plant (WWTP) is screened to remove organic matter and grit larger than 3mm prior to entering the membrane bioreactor (MBR), which is where the influent is biologically treated. The sludge from the secondary treatment process is directed to the Kubota flat sheet membrane for thickening prior to disposal. The Kubota membranes dewater the sludge to approximate 2-3% solids content. The filtrate from the sludge thickening flows back to the MBR via gravity for further treatment. The current process for the Ganges WWTP is illustrated in Figure 1. The thickened sludge is then hauled to the Burgoyne septage receiving facility for disposal. Annually, the Ganges WWTP disposes of 1,599 m³ of sludge (351,770 igal, approximately one 1,200 igal truck every 2 days)¹ costing an average of \$137,190/year² for disposal. Currently, the Burgoyne septage receiving facility charges are \$85.788/m³ (\$0.39/igal).

Recently, operations staff have noticed breakthrough of total suspended solids during sludge thickening indicating that the sludge thickening membrane is not functioning as designed and requires replacement.

As is standard practice, a thorough evaluation of the current technologies available and space requirements will be conducted prior to proceeding with detailed design. In addition, a lifecycle cost analysis will be used to determine the most economic and effective process, based upon: operation, maintenance and capital costs.

In 2011, Stantec was retained and produced an Asset Condition Evaluation and Engineering Study report. The report had made the following statement:

"Next to labour cost, the most expensive item is sludge hauling and disposal with an annual cost of \$128,000. The flat plate membrane system used for sludge thickening produces sludge with a solids content of 2% to 3%. Any improvement in the efficiency of sludge thickening could have a significant impact on reducing the cost of sludge hauling and disposing. In light of the high cost of sludge thickening, this should only be considered when the plant reaches capacity and is expanded in 2022. If carried out, this would reduce the sludge disposal cost by 50%."

In discussions with Stantec regarding clarification to the above statement, Stantec has reinforced that considerable capital costs would be required to incorporate another sludge

¹ Average of 2012 & 2013 operational information

² Average disposal cost at Burgoyne Bay.

thickening technology, and as such, the Burgoyne facility will experience a corresponding reduction in revenue due to the reduced sludge volume.

The Commission has raised concerns that there may be other more cost effective methods for sludge thickening considering the high costs of disposal at Burgoyne and on Stantec's comment in their report. This report will conduct a preliminary lifecycle analysis of two options for sludge disposal.

Current - Membrane Sludge Thickening Capital & Waste Disposal Costs:

To replace the current membrane sludge thickening process a new membrane and a new tank is required. The Class D cost estimate for both is \$500,000³.

The current average annual operating costs for sludge hauling and disposal are comprised of the following:

Annual Average Sludge Disposal <u>Budgeted Sludge Hauling</u> ⁴	\$137,190 \$ 30,000
Total	\$167 190

The tipping fee at Burgoyne or negotiated hauling rate is subject to change.

The total operation costs are estimated to be \$167,190, excluding BC Hydro costs.

Proposed - Fournier Filter Press Thickening Capital & Waste Disposal Costs:

Typically, a pilot study of the proposed process technology is carried out to determine the process efficiency, chemical dosing rate, evaluate overall process performance, and determine order of magnitude operating and maintenance costs. A pilot study is usually a scaled down operation of the proposed process. Since a pilot has not been conducted, the Saanich Peninsula Wastewater Treatment Plant (SPWWTP) operational data for its Fournier Filter Press is used for the basis of comparison. Operational costs are pro-rated based on the volume or weight of sludge produced, the SPWWTP's filter press efficiency for dewatering are assumed to be the same as the sludge produced at Ganges. Past operational experience with GE membrane bioreactor's (MBR), and confirmed through discussions with GE ZENON representatives have indicated that most filter presses require fiber supplicants and/or additional polymer as MBR sludge is typically low in fibre and hard to retain on the filter.

As part of the Fournier filter process a chemical polymer is added to the wastewater sludge, which increases the solids retention on the filter element to avoid solids breakthrough into the effluent. The end products from the sludge are a biosolid, which is discharged into a bin for disposal, and an filtrate which is recycled back into the wastewater stream for UV disinfection prior to discharge via the outfall. The Fournier filter process is illustrated in Figure 2.

³ 2015 Schedule G for the Ganges Sewer Local Service

⁴ 2014 Ganges Sewer Local Service Operating Budget, subject to hauling contract renewal

To accommodate a Fournier Filter Press at Ganges, infrastructure is required for the following facilities and equipment:

- Building an enclosure for the filter press, disposal bin and chemical dosing room,
- Odour control, for the purposes of this evaluation a carbon filter with grease filter will be assumed to be sufficient, and
- Chemical polymer dosing pump, mechanical piping, mixer, etc.

A building is required for the new mechanical equipment, chemical storage, odour containment and treatment, and dry storage of biosolids. It is advantageous to construct a single building to house the entire process as it will simplify odour control and satisfy all the above requirements. We received the enclosure option presented by Waste 'n Watertech, but it does not address odour control for the biosolids, does not house the biosolid bin(s) to ensure rainwater does not re-wet the biosolids and does not house the separate polymer chemical room. For these reasons a building was chosen to house the Fournier Filter Press and associated equipment.

The estimated capital cost (Class D) of this option is \$1,420,000. The breakdown of the estimated capital costs is in Appendix A. The cost of electricity has not been included and is not required for this type of evaluation, but will be more than the current sludge thickening process.

To determine the operational costs for a filter press, the following annual costs are required:

- Sludge volume & weight,
- Polymer requirement,
- Carbon requirement,
- · Tipping fee at Hartland Landfill,
- Hauling of cake, and
- Additional operations and maintenance for additional equipment.

The methodology for determining the costs and the operational cost estimate are in Appendix B. The Class D estimate for the Sludge Filter Press is **\$220,000**, excluding BC Hydro costs. A summary breakdown comprises of the following:

Annual Average Sludge Disposal	\$79,000
Annual Average Sludge Hauling	\$78,000
Production Costs	\$63,000
Total	\$220,000

In addition to the costs associated with the addition of a Fournier Filter Press, the location of the Fournier Filter Press building may be difficult to site. The zoning has not been investigated, but conceptual massing of the most likely location is in Figure 3. Issues with the location are its proximity to the influent pump station and ensuring truck access to the screen and MBR.

15 Year Lifecycle Cost Comparison

To properly compare the two options, the total lifecycle cost of each technology is considered for the Fournier Filter Press, which has the longer life expectancy of 15 years, and the membrane sludge thickening which has a life expectancy of 10 years. Operational costs for both scenarios are assumed to increase at a rate of 2% annually. Capital costs for both the

membranes and filter press are incurred at the beginning of the analysis and at their expected replacement year. The 15-year lifecycle costs are illustrated in Figure 4 below:




Figure 4 15 year Lifecycle Cost Comparison

Raw data can be found in Appendix C.

This comparison is only order of magnitude and likely does not capture all costs. An in depth investigation is required to capture majority of the costs and address issues such as total lifecycle operation and maintenance costs such as building maintenance, heating and ventilation requirements and electrical costs.

In addition to the lifecycle cost comparison, a net present value comparison over 30 years was conducted to determine the total investment required for both options. A 30 year period was chosen as it resulted ended on a year in which both option's equipment would need to be replaced, and a discount rate of 5% based on the an estimated average loan interest rate was utilized. The net present values calculated over 30 years are:

Option	Net Present Value (2014)
Existing Membrane Sludge Thickening	(-)\$4,934,000
Fournier Filter Press	(-)\$6,703,000

From the net present value comparison, it is apparent that the existing membrane sludge thickening option incurs the least amount of cost.

The improvement of the water removal from the sludge will have undesired impact decrease in the capacity of the MBR, with an increased filtrate volume returned to the MBR in the order of 3 m³/d. The increase in filtrate from the dewatered sludge is returned back to the MBR tank so that it is properly filtered and passes through the UV equipment. Disinfection is currently a requirement of discharge so this process will remain. The amount of filtrate returned has a direct impact on the capacity of the Ganges WWTP, effectively reducing it by the amount of filtrate returned to the MBR. This will need to be accounted for when evaluating the processes, but is not part of this report.

Additionally, the sludge produced from the Fournier filter presses cannot currently be handled by the Burgoyne septage receiving facility. Sludge produced with this method will have to be hauled to the Hartland Landfill for disposal. This will result in higher hauling costs and reduced revenue for the Burgoyne facility.

ALTERNATIVES

That the Ganges Sewer Local Service Commission:

- 1. Receive this staff report for information and review options at the preliminary design stage as initially envisioned for this project.
- a) Receive this staff report for information and direct CRD staff to evaluate sludge thickening technologies before proceeding with replacing the sludge thickening membranes.
 - b) Approve a budget of \$35,000, funded from the capital reserves, for the evaluation work.

IMPLICATIONS

Alternative 1 – By proceeding as originally intended the project will not be delayed. The staff will select the lowest capital, operating, maintenance and lifecycle cost for the project.

Alternative 2 – By proceeding with the review the overall project will be delayed, potentially resulting in compliancy issues and/or equipment repairs or failures.

CONCLUSION

The existing sludge thickening membrane has provided 10 years of reliable and effective operation but it is at its end of serviceable life. The cost comparison between the current technology and a Fournier Filter Press is more complicated than just comparing disposal and hauling costs, a holistic approach for comparison is required. An in depth evaluation of available options will be carried out as part of preliminary design, as is standard engineering practice. The lowest capital, maintenance, operating and lifecycle option will be presented to the commission for consideration.

RECOMMENDATION

That the Ganges Sewer Local Service Commission receive this staff report for information and review options at the preliminary design stage as initially envisioned for this project.

Dale Puskas, P.Eng. Project Engineer Infrastructure Engineering and Operations Craig Gottfred, P.Eng.
Manager, Wastewater Engineering and Planning
Infrastructure Engineering and Operations

Peter Sparanese, P.Eng. Senior Manager, Infrastructure Engineering and Operations Concurrence Ted Robbins, BSc, C.Tech. General Manager, Integrated Water Services Concurrence


Attachments:

Figures 1, 2 and 3

Appendix A - Fournier Filter Press Capital Estimate

Appendix B – Ganges Fournier Filter Press Operational Cost Methodology and Estimate

Appendix C – Lifecycle Cost Raw Data







Figure 2: Typical Fournier Filter Press Process



APPENDIX A

		ANGES	SEW	ER LO	GANGES SEWER LOCAL SERVICE	ERVICE	}			4	epare	Date: Ned by: I	loven Dale F	Date: November 24, 2014 Prepared by: Dale Puskas, P.Eng.
Making a differencetogether		EK PR	E22	AP	FILLER PRESS CAPITAL ESTIMATE	MIME	I E							Page 1 of 1
Description	Details	Bulburg	2015 Estimated Construction		Constitued of the constituent of	lelolans	ENBINEER	Salaganga Salagang		Admin (%)	ONEIBHO	sioneiado sioneiado	Hers	MOI
	=	5	CAPITAL REQUIREMENTS	JIREME	VTS				E				ľ	
Building	Construct a wood framed building to house the filter press and disposal bin.	Captial	402,000	SS	201,000	603,000	20	120,600	'n	30,150	10	60,300	s,	810,000
Filter Press	Supply and install a filter press and minor associated mechanical.	Capital	300,000	S	150,000	450,000	20	000'06	'n	22,500	10	45,000	w	610,000
Mechanical Work including piping	Supply and construct mechanical piping associated with filter press	Capital	20,000	95	10,000	30,000	50	9000	'n	1,500	10	3,000	v	40,000
Carbon Filter	Supply and install carbon filter, including grease filter, for odour control	Capital	30,000	80	15,000	45,000	20	9,000	s	2,250	10	4,500	vs.	000'09
	TOTAL COST OF ESTIMATED CAPITAL REQUIREMENTS	OF ESTIMAT	ED CAPITA	L REQUI	REMENTS								\$ 1,420,000	20,000

APPENDIX B

GANGES FILTER PRESS OPERATION COST METHODOLOGY

Use Saanich Peninsula Wastewater Treatment Plant (SPWWTP) information for determination of sludge solids content, efficiency of Fournier Press and polymer usage:

- Average polymer addition ~ 0.54% kg polymer per kg sludge
- Blend Tank solids average ~ 28% of total sludge volume
- Sludge solids content (m³/m³) ~ 3.5%, close to the 2-3% at Ganges WWTP
- Hauling cost for a 10 tonne/truck ~ \$118/truck excluding trucking hours & ferry
- 22' bin for disposal, truck and bin ~ 30'

BC Ferries Fare for Hauling:

3.65/ft commercial rate + 3.4% fuel surcharge = 30° x 3.65/ft x 1.034 = 1.

Estimated Trucking Hours:

Approximately 6 hours round trip, therefore 6hrs x \$135/hr = \$810/truck

Total Hauling Cost/truck:

\$118 + \$113 + \$810 = \$1,041/truck

Ganges Sludge Estimation:

Current annual average sludge generation ~ 351,770 igal (1,599.2 m³) based on volumes billed to Ganges from Burgoyne for 2013 and 2012.

Cake Solids Volume $\sim 1,599.2 \text{ m}^3 \times 28\% = 447.8 \text{ m}^3$

Assuming density still close to water therefore weight = $447.8 \text{ m}^3 \text{ x} 1,000 \text{ kg/m}^3 = 447,800 \text{ kg}$

Polymer required 1,599.2 m^3 x 3.5% = 55,972 kg sludge x 0.54% = 302 kg Polymer cost \$7.75/kg therefore \$2,340

Hartland disposal costs \$117/tonne, therefore [447,800 kg + 302 kg] x \$117/tonne = **\$52,427**

Number of trucks/year ~ [447,800 kg + 302 kg] / 10 tonne/truck = 45 pick-ups/year, add 10% due to pick-ups falling on long weekend or weekend, therefore ~ 50 trucks/year

Hauling Cost = $$1,041/\text{truck} \times 50 \text{ trucks} = $52,050$

Additional operations and maintenance labour required for additional equipment ~ 4 hrs per week at \$100/hr = \$20,800/year

Assume granular activated carbon needs to be replaced 1/year; approximate cost is \$165/ft³ (\$5,826/m³). Similar facility use a 114 ft³ (3.23 m³) filter therefore carbon cost is **\$18,800**

^{**}Relationships are derived imperically.

Making a differencetogether		FILTER	GANGES SEWER UTILITY R PRESS OPERATING ESTI	EWEK	GANGES SEWER UTILITY FILTER PRESS OPERATING ESTIMATE	TE						Prepa	Prepared by: Dale Puskas, P.Eng. Page 1 of 1
Description	Details	Punding Source	2015 Estimated Constitution	Tonegener (SE)	ASUR SELECT	lelolqns	Britoshing [Se]	Engineering	(SE) MITTOPA	almba	enoliterado	uonesado	MOI
			SLUDGE DISPOSAL	POSAL								M	
Disposal	Disposal cost of biosolids at Hartland	Operation	52,427	05	26,214	78,641	0	0	0	0	0	0	\$ 78,641
			SLUDGE HAULING	OLING									
Hauling	Haul biosolids from Ganges to Hartland	Operation	52,052	20	26,026	78,078	0	0	0	0	0	0	\$ 78,078
		S	SLUDGE PRODUCTION	UCTION									
Granular Activated Carbon	Annual supply of activated carbon	Operation	18,800	S	9,400	28,200	0	0	0	0	0	0	\$ 28,200
Polymer Supply	Polymer supply to achieve dewatering with a filter press	Operation	2,340	8	1,170	3,510	0	0	0	0	0	0	\$ 3,510
Additional Labour for Equipment	Estimated cost for additional labour with the operations of the filter press and odour control	Operation	20,800	S	10,400	31,200	0	0	0	0	0	0	\$ 31,200
	TOTAL COST OF ESTIMATED ANNUAL OPERATIONS & MAINTENANCE	MATED ANN	UAL OPER	ATIONS 8	MAINTEN	ANCE							\$ 219,629

APPENDIX C

	ting Membr	ane Sludge	Thickene	r		Four	nier Filter P	ress	
Expenditures	Cost		Cumulative	Costs	Expenditure	Cost		Cumulativ	re Costs
New Capital & Annu	cal				New Capital & Annual				
1 Disposal Costs	s s	663,670	\$	663 670	Disposal Costs	\$	1,639,629	\$	1,639,6
2 Annual Disposal Cos	it S	166,943	\$		Hauling	\$	224,021	\$	1,863,6
3 Annual Disposal Cos		170,282	\$		Annual Disposal Cost	\$	228,501	\$	2,092,1
4 Annual Disposal Cos		170,282	\$, ,	1			1 '	
5 Annual Disposal Cos		177,162		1,174,584	Annual Disposal Cost	\$	233,072		2,325,2
6 Annual Disposal Cos		180,705	\$		Annual Disposal Cost	\$ \$	237,733	\$ \$	2,562,9
7 Annual Disposal Cos		-	\$	1,532,450	Annual Disposal Cost		242,488		2,805,4
8 Annual Disposal Cos		184,319	\$	1,716,769	Annual Disposal Cost	\$	247,337	\$	3,052,7
9 Annual Disposal Cos	£ '	188,005	\$	1,904,775	Annual Disposal Cost	\$	252,284	\$	3,305,0
,	I '	191,765	\$		Annual Disposal Cost	\$	257,330		3,562,3
10 Annual Disposal Cos	' 1 '	545,601	1		Annual Disposal Cost & C		262,476		3,824,8
11 Annual Disposal Cos	1 '	199,513	\$		Annual Disposal Cost	\$	267,726	\$	4,092,5
12 Annual Disposal Cos	1 '	203,503	\$		Annual Disposal Cost	\$	273,080	\$	4,365,6
13 Annual Disposal Cos	1 '	207,573	\$. ,	Annual Disposal Cost	\$	278,542		4,644,2
14 Annual Disposal Cos	t \$	211,725	\$	3,464,454	Annual Disposal Cost	\$	284,113	\$	4,928,3
					Annual Disposal Cost &				
15 Annual Disposal Cos	t \$	215,959	\$	3,680,414	Capital Replacement	\$	539,795	\$	5,468,1
16 Annual Disposal Cos	t \$	220,278	\$	3,900,692	Annual Disposal Cost	\$	295,591	\$	5,763,7
17 Annual Disposal Cos	t \$	224,684	\$	4,125,376	Annual Disposal Cost	\$	301,503	\$	6,065,2
18 Annual Disposal Cos	t \$	229,178	\$	4,354,553	Annual Disposal Cost	\$	307,533	\$	6,372,7
19 Annual Disposal Cos	t \$	233,761	\$	4,588,314	Annual Disposal Cost	\$	313,684	\$	6,686,4
Annual Disposal Cos	t&								
20 Capital Replacement	: \$	738,436	\$	5.326.751	Annual Disposal Cost	\$	319,957	\$	7,006,3
21 Annual Disposal Cos		243,205	\$		Annual Disposal Cost	Ś	326,356	Ś	7,332,7
22 Annual Disposal Cos		248,069	\$		Annual Disposal Cost	\$	332,884	\$	7,665,6
23 Annual Disposal Cost		253,030	\$		Annual Disposal Cost	\$	339,541	Š	8,005,1
24 Annual Disposal Cost		258,091	\$		Annual Disposal Cost	\$	346,332	1 *	8,351,5
25 Annual Disposal Cost		263,253			Annual Disposal Cost	\$		\$	8,704,7
26 Annual Disposal Cost		268,518			Annual Disposal Cost	\$	360,324		9,065,0
27 Annual Disposal Cos		273,888	-		Annual Disposal Cost	\$	367,530	-	9,432,6
28 Annual Disposal Cost	\$	279,366			Annual Disposal Cost	\$	374,881	1	9,807,9
29 Annual Disposal Cost		284,953	-		Annual Disposal Cost	\$	382,379	'	10,189,
Annual Disposal Cost					Annual Disposal Cost &				
30 Capital Replacement		640 CE3	ė			_	500.005		10,879,9
solcabital replacement	. \$	640,653	>	8,339,778	Capital Replacement	\$	690,026	۶ ا	10,87



REPORT TO GANGES SEWER LOCAL SERVICE COMMISSION MEETING OF THURSDAY, JANUARY 8, 2015

SUBJECT

GANGES SEWER INFRASTRUCTURE REPLACEMENT PROJECT-RESULTS OF THE PUBLIC OPEN HOUSE MEETING

ISSUE

The purpose of this report is to summarize the results of the Public Open House meeting on December 2, 2014 and the feedback received to inform the Ganges Sewer Local Services Commission, as well as identify the next steps in the sewer infrastructure replacement project.

BACKGROUND

At a meeting on October 23, 2014, the Ganges Sewer Local Service Commission approved the following recommendation:

b) funding the Public Engagement Strategy in the amount of \$4,000 from the capital reserve.

The purpose of the Public Open House was to:

- 1. To consult with Ganges Sewer Local Service Area residents who are on the Ganges sewer system about the proposed infrastructure upgrades.
- To inform Ganges Sewer Local Service Area residents and stakeholders who are on the Ganges sewer system about the scope, implications and cost of the planned infrastructure upgrades. The open house presentation material will cover background information on the upgrades, preparing the public for a referendum vote on whether to undertake the improvement project.

As a result, on Tuesday, December 2, 2014, the Capital Regional District (CRD) staff and the commission held a Public Open House meeting between 1–3 pm and 4–6 pm at the Salt Spring Island Public Library, 129 McPhillips Avenue, Ganges for the Ganges Sewer System Infrastructure Replacement project. CRD staff presented, in a story board format, the various options (3) and the option (1) recommended by CRD staff.

The Public Open House had approximately 30 attendees. CRD staff and various commission members were in attendance at the meeting to answer any questions. Feedback from residents of the service area regarding the Public Open House was received until December 14, 2014. The number of feedback forms received, both by mail, hand and electronically, totalled 9. While this level of participation is not statistically relevant, the responses to certain questions does provide insight as to which direction the Commission may wish to explore.

The summary of the Public Open House feedback is as follows:

Q1. Do you feel that you have received enough information and have a good understanding of the issues and challenges associated with the Ganges wastewater system?

A1. Yes 5 No 4

If you answered no, what additional information do you need? This information is in the attached feedback forms – Appendix A

Q2. Which of the three options presented do you prefer and why?

A2. Option 1 (CRD recommendation) 6
Option 2 0
Option 3 0
None selected 3
Reasons:

This information is in the attached feedback forms - Appendix A

Q4. If Option1 is chosen, would you prefer a 15-year or 25-year period for the loan amortization?

A4. 15 year 4 25 year 3 Other 2

Further comments regarding the proposed works and the Ganges wastewater system have been summarized in the Appendix A.

ALTERNATIVES

Alternative 1

That the Ganges Sewer Local Service Commission:

- 1. Receive the Public Open House results for information purposes;
- 2. Approve Option1 in the amount of \$3,900,000 as recommended by CRD staff;
- 3. Approve preparation of New Building Canada Fund Small Communities grant request based on scope as identified in Option 1; and
- Approve funding for the Referendum process in the amount of \$10,000 from capital reserves.

Alternative 2

That the Ganges Sewer Local Service Commission:

- 1. Receive the Public Open House results for information purposes; and
- 2. Approve funding a Community Hall meeting to present the results of the open house meeting to the public in the amount of \$2,500 from capital reserves.

IMPLICATIONS

Alternative 1 – By selecting a preferred option (1), the Commission is able to advance the project and direct CRD staff to prepare a New Building Canada Fund grant request. The deadline for the grant submission is February 18, 2015. However, both the CRD Board and/or Electoral Area Standing Committee would also have to agree with the grant request. The EASC meeting is January 21, 2015. The CRD Board meeting is February 4, 2015.

Alternative 2 — With the receipt of the Public Open House feedback, the Commission would share the results with the community and provide another opportunity for the public to ask additional questions and to provide information from staff regarding the various options presented as outlined in Appendix B. By hosting another public meeting, this will hopefully allow the community to gain further understanding of the issues, options, implications, and next steps.

This alternative will delay implementation of the recommended option and applying for grant funding for the project.

CONCLUSION

The results from the Public Open House, although limited, indicate support for Option 1 based on the options presented at the open house meeting.

If supported by the Commission, the next steps would be to apply for a New Building Canada Fund grant request. The deadline for the grant submission is February 18, 2015.

In addition, CRD staff would prepare for a referendum in the late Spring/early Summer of 2015.

RECOMMENDATION

That the Ganges Sewer Local Services Commission:

That the Ganges Sewer Local Service Commission:

- 1. Receive the Public Open House results for information purposes;
- 2. Approve Option1 in the amount of \$3,900,000 as recommended by CRD staff;
- 3. Approve preparation of New Building Canada Fund Small Communities grant request based on scope as identified in Option 1; and
- 4. Approve funding for the Referendum process in the amount of \$10,000 from capital reserves.

Craig Gottfred, P.Eng.
Manager, Wastewater Engineering and
Planning

Karla Campbell Senior Manager, Salt Spring Island

Peter Sparanese, P.Eng.
Senior Manager, Infrastructure Engineering and Operations
Concurrence

Ted Robbins, B.Sc., C.Tech.
General Manager, Integrated Water Services
Concurrence

CG/PS:Is

Attachments:

Appendix A – Public Feedback Summary Report – Wastewater Infrastructure Replacement Program
Appendix B – Community Hall Meeting in Support of Public Engagement Strategy for Ganges Sewer
System Infrastructure Replacement project



GANGES SEWER LOCAL SERVICE COMMISSION

January 8, 2015


Agenda item 2.2 Results of Public Open House Meeting Appendix A

Ganges Sewer System

Public Feedback Summary Report

Wastewater Infrastructure Replacement Project








Table of Contents

Feedback Summary	3
Consultation	4
Feedback Data	6
Written Answers	10
Appendices	13

Feedback Summary

Total Ganges Sewer System Feedback Forms submitted

Paper Feedback Form: 6 Online Feedback Form: 3

Percentages of total responses indicating whether respondent felt they had received enough information about the project

Enough Information: **56%** Not Enough Information: **44%**

Percentages of total responses identifying a replacement project option

Option 1: 67% Option 2: 0% Option 3: 0%

None Selected: 33%

Percentages of total responses identifying a loan type option


15-Year: **45%** 25-Year: **33%** Other**: **22%**

Top Ranking Criteria Influencing Preferences


Other**
Cost to Property Owner
Environmental Impacts

^{*}Feedback numbers do not necessarily represent one response per person. Response was not required for all questions. Numbers are rounded up.

^{**}See the Written Answers (page 10-12) for further information.



Feedback Form




nly freeback arceived by 1	 	

Feedback Data

Overall Feedback Summary

Question 1: Do you feel that you have received enough information and have a good understanding of the issues and challenges associated with the Ganges Sewer system?

In-Person and Online Feedback (9*)




^{*}Feedback numbers do not necessarily represent one response per person. Response was not required for all questions. Percentages have been rounded to the nearest whole number.

Overall Feedback Summary

Question 2: Which of the three options presented do you prefer and why?


In-Person and Online Feedback



^{*}Feedback numbers do not necessarily represent one response per person. Response was not required for all questions. Percentages have been rounded to the nearest whole number. Numbers have been rounded up.

Overall Feedback Summary

Question 4: Since the majority of the proposed works in Option One have a life expectancy of more than 15 years, the loan could be amortized over a longer period. If Option One is chosen, would you prefer a 15-year or 25-year (smaller annual payments) period?



Question 6: How would you like to receive updates about this project?


In-Person and Online Responses (12*)

Website: 2 Notices in local media: 4

Open House: 4 No updates: 1

Ganges Sewer Commission Meeting: 1

^{*}Feedback numbers do not necessarily represent one response per person. Response was not required for all questions. Percentages have been rounded to the nearest whole number. Numbers have been rounded up.



Written Feedback Summary

Question 1: Do you feel that you have received enough information and have a good understanding of the issues and challenges associated with the Ganges Sewer system?

Need broader context especially in relation to plan location to sea level, climate change

Best information was within Stantec Report – Open house only summarizes.

This is a complicated project. I couldn't really begin to know what is needed.

See back of sheet.

The SAMP is a CRD process that appears not to have been used to generate the proposed project(s). If there is a SAMP I would like to see it. Further I would like to see a SAMP which includes the expected maintenance costs of the three options.

Need breakdown of line item budget costs, project management choice & subcontracting process.

Question 2: Which of the three options presented do you support and why?

(Option 1) This isn't a luxury item, it must be done. We're paying for the sins of the past, when money wasn't put aside for this. Let's put a stop to any further financial neglect.

(Option 1) Short and long term needs met.

(Option 1) Get the sewer system fixed before any more fails.

(Option 1) I'd like to see this facility healthy.

(Option 1) Why procrastinate? The costs are a major concern but we'll have to do the work sooner or later and there doesn't seem to be a reasonable alternative to the overall upgrade. (Option 1) Good balance between engineering needs, cost and time.

(None) I support none of the options. Option 3 is not an option. Items in 1 could be included in 2 and vice versa. There is insufficient agreement between the commissioners and the CRD staff on priorities. There have been too many failed CRD project on Salt Spring. I would need to know more about the project plan and especially the oversight of the budget spending. We need to know the impact on the Ganges business community. With only 417 parcels, option 1 is unsustainable without significant subsidy.

(None) None. The presentation seems to be steering current parcel tax payers to option two. I certainly cannot vote to spend \$1.6M without more detail.

Question 3: Rate the following from the most important (1) to the least important (5) factor that is influencing your answer in the previous question.

Need to focus on big long term picture, not quick fix.

It's the right thing to do – this isn't an "optional" project.

Commissioner/CRD agreement on priorities.

Confidence that the CRD has the optimum solution for this system.

Question 4: Since the majority of the proposed works in Option One have a life expectancy of more than 15 years, the loan could be amortized over a longer period. If Option One is chosen, would you prefer a 15-year or 25-year (smaller annual payments) period?

Would we end up paying a lot more over 25 years? This would be easier on me because I'm not planning to live till 100 yrs old.

The life span of each major sub-project of option 1 should be amortized to either 15 years or 25 years as appropriate.

The list of items short term – 15 year the list of

items long term - 25 year

Please provide any further comments you have on the proposed works and Ganges Sewer system.

1) Relation of plant location to sea level, climate change. 2) Need some longer term perspective - What long term pop to be serviced. Longer terms technology implications. Relation cap. to operating costs. 3) I understand new technology is available that would reduce amount sent to Burgoyne and overall operating costs significantly. Why isn't this an option?


I'm surprised that this facility is in such poor health. I hope we can improve the situation and keep it maintained.

What is the condition of the wastewater outfall pipes out of the harbour? Have they been assessed along with the effluent piping?
 Is the parcel tax the same for each of the 419 taxable folios – regardless of property size or value?
 Interest rates on loans are bound to go up over the long run. The sooner we lock into the initial 10 yr. loan @ 5% - the better.

I would like to receive information by regular mail also. I am very concerned that is the first widespread public communication on the state of the sewer system. Had I been aware of the Stantec report or a SAMP I could have given this more thought and perhaps been in a better position to agree with the decisions as proposed. The CRD director, the Provincial MLA and our Federal MP all need to be involved in finding some infrastructure grant to help fund either Option 1 & 2.

APPENDICES


Appendices



Appendices

- A | Public Open Houses Direct Mail Out
- B | Public Open House Print Ad
- C | Public Open House Handout Frequently Asked Questions
- D | Public Open Houses Display Boards
- E | Sign-In Forms

Appendix A Public Open Houses - Direct Mail-Out





Appendix B Public Open Houses - Print Ad

Capital Regional District

CISID

Notice of Open House

Ganges Sewer Wastewater System

The Capital Regional District (CRO) is working with the Ganges Sewer Local Services Commission (CSESC) to explain the options for addressing the issues facing the aging and failing sewer intrastructure in Ganges. The three options identified all have significant financial impact on the Ganges Sewer rategraphics, and social or environmental impacts on the compression. the community.

The ORO and GSESC invite all residents and business owners on the Ganges sewer system to an Open House to obtain information on issues, options, recommendations, costing and implications, complete the survey and to provide their feedback.

Oale: Tuesday, December 2, 2014
Time: 1pm to 3pm ANO 4pm to 6pm (Drop-In)
Location: Salt Spring Island Public Library, 129 McPhillips Ave.

If you are unable to attend the open house or would like to view

www.cdb.ca/ganges sewer. The feedback survey from the open-house will also be available on the project website at to December 14, 2014 for those who would like additional time or for those will also be available on the project website from December 2 to December 14, 2014 for those who would like additional time or for those who are unable to attend the open house.

Keith Wahlstrom, PEng. Manager, Engineering Salt Spring Island Bectoral Area Tel: 250,537,4448 Email kwahlstrom@ord.bc.ca


marked be daying is served


Appendix C Frequently Asked Questions






Appendix D Public Open House - Displays

























APPENDIX D | OPEN HOUSE DISPLAYS




APPENDIX E | SIGN-IN SHEETS

Appendix E Public Open House - Sign-In Sheet

Question 1: How did you hear about this event?

Number of attendees on sign-in form

(25* - 15 at first session, 10 at second session)



^{*}Feedback numbers do not necessarily represent one response per person. Response was not required for all questions. Percentages have been rounded to the nearest whole number. Numbers have been rounded up.



GANGES SEWER LOCAL SERVICE COMMISSION

January 8, 2015

Agenda item 2.2 Results of Public Open House Meeting Appendix B

ATTACHMENT: Community Hall in Support of Public Engagement Strategy for Ganges Sewer System Improvement Program

Purpose

- 1. To present feedback results from Open House and Online to residents who are on the Ganges sewer system.
- 2. To provide a chance for residents to ask questions of CRD staff and Ganges Sewer Local Services Commission members.

Proposed Strategy

The strategy includes hosting a follow-up, community hall meeting on Salt Spring Island Island for residents who are on the Ganges sewer system to attend. At the meeting, there will be a PowerPoint presentation on updates to the project and results of the feedback and a question-and-answer period for residents to ask questions of CRD staff and Ganges Sewer Local Services Commission members. Experts will attend the session to answer any questions and hear any concerns that attendees express with the goal to have meaningful conversations about the project. The open house will be promoted using the project website, direct mail-out invitation to customers of the Ganges sewer system.

Budget – Ganges Town-Hall Meeting	\$2500
Materials (Printing, Signage, Copies of Report Summary)	\$400
Open House (Rental, 5 hours)	\$150
Travel (Vehicle Rental, Ferry)	\$200
Refreshments	\$750
Promotion (Mail-Out, Website)	\$1000

Detailed Public Engagement Plan

To be created once Commission decides on most appropriate improvement program and approves funding for public engagement activities.