

**TO:** All Tenderers

**FROM:** McElhanney Consulting Services Ltd.; Victoria, BC

**DATE:** August 18, 2017

**PROJECT:** **CRD Tender 2017-311 – Port Renfrew Watermain Replacement**

**FILE NO:** 2243-17060

---

**1. Clarifications:**

- a. Excavated material can be used as backfill if approved by the Contractors Geotechnical Engineer. A unit item has been added to the Schedule of Prices and Estimated Quantities for the Contractor to provide a credit for material re-use.
- b. Excavated material, not being re-used for backfill, must be removed from site. No side casting, or dumping of excess material on-site will be permitted.

**2. Tender Document:**

- a. Schedule of Unit Prices and Estimated Quantities: Please replace with the attached Schedule. Item 33.15 has been added to the required works section to provide a credit for the re-use of native material as backfill, and item 33.12 has been added to the provisional works section to provide a credit for the re-use of native material as backfill.
- b. Annexures: The following Annexures, identified on page 18, have been included in the Addendum for reference:
  - i. Environmental Assessment Overview (EA) for the CRD Watermain Replacement Project, Port Renfrew BC, June 23, 2017
  - ii. Capital Regional District Port Renfrew Watermain Replacement Preliminary Geotechnical Assessment June 27, 2017

**3. Design Drawings**

- a. Revised drawings 5587-1-6, and 5887-8, have been included.

Attachments:

1. Updated Schedule of Unit Prices and Estimated Quantities
2. Environmental Impact Assessment
3. Preliminary Geotechnical Assessment
4. Revised drawings 5587-1-6, and 5887-8

**END OF ADDENDUM #1**