



Making a difference...together

ADDENDUM NO. 1

to the

INVITATION TO TENDER DOCUMENTS for

OLD CRAIGFLOWER PUMP STATION DEMOLITION

CONTRACT 2019-476

To All Respondents:

May 14, 2019

The following changes, additions, and/or deletions are hereby made a part of the Contract Documents for Capital Regional District, Old Craigflower Pump Station, Contract 2019-476 as fully and completely as if the same were fully set forth therein:

- 1. Minutes of the Pre-Contract Meeting** – see attached
- 2. Supplemental General Conditions**
 - a. **DELETE** Section 67 REFERENCE ARTICLE – 30 GUARANTEE PERIOD in its entirety.

End of addendum.

OLD CRAIGFLOWER PUMP STATION DEMOLITION
2019-476 Pre-Contract Award Meeting
May 9, 2019, 2760 Shoreline Drive, 2:00 pm

Attendees: Dale Puskas, CRD
Roger Smith, Cats Eye Cont.
Brad Wilkerson, Ralmax
Steve Browne, Ralmax
Larry Adams, Enviro-Vac
Lindsay Cooper, Shell Construction Group

1. Brief outline of scope of works, some minor changes since 2017 tender, with two key changes:
 - a. Required demolition depth of structure changed from existing ground level to 1 m below ground; and
 - b. Removal of black vinyl chain link fence and use of temporary snow fence.

2. Questions asked at the meeting:

Is a guarantee period of 1 year required for a demolition?

No, Addendum 1 will address.

Is 12" minus granular required for fill as specified? Can it be pea gravel?

We are confirming with our geotechnical engineer the use of pea gravel, as noted in Section 31 05 16, 3.4.3 Alternative Infill concrete and controlled density fill are also approved infill materials provided they meet the specifications.

Is the schedule a hard deadline?

The working period from July 2nd to August 23rd, 2019 is a set schedule so that demolition does not impact the regular school year. The pump station is in a right-of-way on school grounds.

Meeting adjourned at 2:45 am