

BID DOCUMENTS FOR
SOOKE LAKE INTAKE TOWER REMEDIATION

4/17/2019
FILE: 115618065

TENDER #: 2019-492

ISSUED BY: _____

Bryan Gallagher, P.Eng.
Stantec Consulting Ltd.
Tel: (250) 388-9161
Fax: (250) 382-0514
Bryan.gallagher@stantec.com

Addendum issued to active tenderers with documents on record **(1 page, no attachments)**

Clarifications and Additions:

1. The non-mandatory pre-tender site meeting information included with the Tender documents (Invitation to Tender, page 10) is revised as follows:

A non-mandatory pre-tender site meeting to review the Sooke Lake Intake site will be held on Wednesday April 24, 2019. Contractors interested in attending the site meeting are to meet at the Goldstream Gate entrance to the Sooke Lake Watershed (furthest west public access of Sooke Lake Road) **at 9:00am local time**. The CRD will provide a vehicle escort from the Goldstream Gate to the Sooke Lake Dam site (25 km on active logging roads). Four-wheel drive vehicles are recommended. This will be the only opportunity to visit the site during the tender period.

2. Commissioning of Hoists (Specification Section 01 91 00 clause 1.9-8-6.1 is revised as follows:

Provide and install capacity name plates beside each lifting hook/hoist. Perform load test with test weight(s) to **125%** of the rated capacity of each hoist **in accordance with WorkSafeBC requirements**.

Distribution:

Capital Regional District Integrated Water Service to post on the bid site