



Making a difference...together

## **ADDENDUM NO. 2**

to the

INVITATION TO TENDER DOCUMENTS for

SPWS – Upper Dean Reservoir Roof Replacement

CONTRACT 2021-690

To All Respondents:

June 10, 2021

The following changes, additions, and/or deletions are hereby made a part of the Contract Documents for Capital Regional District, Upper Dean Reservoir Roof Replacement, Contract 2021-690 as fully and completely as if the same were fully set forth therein:

Please see the attached information:

Question #1:

Would you please confirm that the only painting required on this project is to the guard rails?

Answer #1:

The only painting required is to the guard rails.

Question #2:

A couple of questions also. In regards to the tie back wire for the telephone pole is this being looked after on your end, and also having the low voltage wires being off the roof level 8ft are we to allow for a heat shield to ensure adequate protection of wires?

Answer #2:

Tying back the wire for the hydro pole is part of the contractors scope and clearly shown on the drawing.

The contractor is responsible for site safety and protecting any existing services. They need to decide what level of protection is adequate for existing wires. This is clearly outlined in the drawing and spec package.

Question #3:

Will the CRD approve alternate materials, such as a flameless SBS roof?

Answer #3:

Please submit your bid as per the tender documents specifications and drawings. After award of contract to successful bidder, the CRD may consider alternate materials as long as they meet the criteria for the RCABC Gold Star 10 Year Warranty.

**End of addendum.**