



**NOTE:**

1. ALL MATERIALS MUST CONFORM TO APPROVED CRDWS ENGINEERING SPECIFICATIONS.
2. IF CUSTOMER SERVICE LINE IS ALREADY IN PLACE, CRD WILL CONNECT LINE DIRECTLY TO CHECK VALVE PROVIDED PIPE IS INSTALLED CORRECTLY.
3. METER BOX AND LID TO BE H20 LOAD RATED DFW PLASTICS INC. DFW486WBC4-12-AF4FM DEEP OR APPROVED EQUAL.
4. SERVICE LINE TO BE CROSS-LINKED POLYETHYLENE-MUNICIPEX OR APPROVED EQUAL c/w STAINLESS STEEL PIPE INSERT AT EACH END OF SERVICE PIPE. INSERT TO BE MUELLER WATER PRODUCTS PART NUMBER 504385 FOR 25mm diameter SERVICES AND 504281 FOR 19mm diameter SERVICES OR APPROVED EQUAL. TRACER WIRE TO BE DECA CABLES 20-705 OR APPROVED EQUAL. FASTEN TRACER WIRE TO SERVICE LINE WITH ZIP TIES AT REGULAR INTERVALS. EACH BARE END TO BE TERMINATED WITH UNDERGROUND LOW VOLTAGE WATERPROOF CONNECTORS.



STANDARD WATER SERVICE CONNECTION  
19mm & 25mm

revision date: DEC 2016	scale: N.T.S.
drawn: BB	checked: J. MAR
standard drawing no.: 2.6	