


**ORDINARY BEDDING DETAIL**

**DETAIL OF INSTALLATION WHERE MINIMUM COVER CANNOT BE ATTAINED**

NOTES:

1. UNDER THE TRAVELLED PORTION OF ROADS AND DRIVEWAYS OR WITHIN 1.5M FROM THE EDGE OF TRAVELLED ROADWAY, THE TRENCH SHALL BE BACKFILLED WITH COMPACTED IMPORTED BACKFILL UP TO 300mm BELOW ROAD SURFACE, THE REMAINING TRENCH TO BE BACKFILLED WITH 25mm MINUS CRUSHED ROAD GRAVEL.
2. CONTROLLED DENSITY BACKFILL MAY BE USED IN LIEU OF IMPORTED OR SELECT BACKFILL AND GRANULAR BASE.
3. D = OUTSIDE PIPE DIAMETER




BEDDING

25mm MINUS CRUSHED ROAD BASE AS PER STANDARD DRAWING 4.4




IMPORTED OR SELECTED BACKFILL

75mm MINUS CRUSHED ROAD BASE COMPACTED TO 95% MODIFIED PROCTOR DENSITY.



APPROVED NATIVE BACKFILL

NO ROOTS, STUMPS OR OTHER ORGANIC MATERIAL. ANY MATERIAL FREE OF STONES LARGER THAN 150mm.



ROAD BASE

SAME AS BEDDING



Making a difference...together

**STANDARD TRENCH  
DETAIL**

|                              |                         |
|------------------------------|-------------------------|
| revision date:<br>APRIL 2007 | scale:<br>N.T.S.        |
| drawn:<br>PJ/GP              | checked:<br>C. GOTTFRED |

standard drawing no.:

**1.12**