



NOTES:

- 1. TRENCH DAMS TO BE CONSTRUCTED:
 - ON PIPE INSTALLATIONS WITH 10% to 15% SLOPE, NOT MORE THAN 30 METER APART ON PIPE INSTALLATIONS WITH 15% to 30% SLOPE, NOT MORE THAN 15 METER APART

 - AS DIRECTED BY THE ENGINEER ON SITE WHERE PIPE INSTALLATION EXCEEDS 30% REFER TO STANDARD DRAWING 4.10



TRENCH DAMS FOR SLOPES TO 30%

revision date:	scale:
JUNE 2009	N.T.S.
drawn:	checked: C. GOTTFRED
PJ/FH	C. GOTTFRED
standard drawing no.:	
4 11	