

**CAPITAL REGIONAL DISTRICT - INTEGRATED WATER SERVICES****Water Watch**

Issued December 29, 2020

**Water Supply System Summary:****1. Useable Volume in Storage:**

Reservoir	December 31 5 Year Ave		December 31/19		December 27/20		% Existing Full Storage
	ML	MIG	ML	MIG	ML	MIG	
Sooke	88,856	19,548	73,370	16,141	92,727	20,400	100.0%
Goldstream	7,109	1,564	4,889	1,075	9,096	2,001	91.7%
Total	95,965	21,112	78,259	17,217	101,823	22,401	99.3%

**2. Average Daily Demand:**

For the month of December	100.5 MLD	22.10 MIGD
For week ending December 27, 2020	98.6 MLD	21.69 MIGD
Max. day December 2020, to date:	107.8 MLD	23.71 MIGD

**3. Average 5 Year Daily Demand for December**

Average (2015 - 2019)	95.6 MLD <sup>1</sup>	21.03 MIGD <sup>2</sup>
-----------------------	-----------------------	-------------------------

<sup>1</sup>MLD = Million Litres Per Day      <sup>2</sup>MIGD = Million Imperial Gallons Per Day**4. Rainfall December:**

Average (1914 - 2019):	293.4 mm
Actual Rainfall to Date	279.2 mm (95% of monthly average)

**5. Rainfall: Sep 1- Dec 27**

Average (1914 - 2019):	752.3 mm
2020	863.0 mm (115% of average)

**6. Water Conservation Action Required:**

To avoid possible leaks this spring, now is the time to winterize your sprinkler system.  
Visit [www.crd.bc.ca/water](http://www.crd.bc.ca/water) for more information.

If you require further information, please contact:

Ted Robbins, B.Sc., C.Tech  
General Manager, CRD - Integrated Water Services  
or  
Glenn Harris, Ph D., RPBio  
Senior Manager - Environmental Protection

Capital Regional District Integrated Water Services  
479 Island Highway  
Victoria, BC V9B 1H7  
(250) 474-9600