

**CAPITAL REGIONAL DISTRICT - INTEGRATED WATER SERVICES****Water Watch**

Issued September 08, 2020

**Water Supply System Summary:****1. Useable Volume in Storage:**

Reservoir	September 30 5 Year Ave		September 30/19		September 6/20		% Existing Full Storage
	ML	MIG	ML	MIG	ML	MIG	
Sooke	63,429	13,954	64,289	14,144	68,078	14,977	73.4%
Goldstream	5,377	1,183	4,117	906	6,685	1,471	67.4%
Total	68,806	15,137	68,406	15,049	74,763	16,448	72.9%

**2. Average Daily Demand:**

For the month of September	187.0 MLD	41.13 MIGD
For week ending September 06, 2020	184.3 MLD	40.55 MIGD
Max. day September 2020, to date:	200.1 MLD	44.03 MIGD

**3. Average 5 Year Daily Demand for September**

Average (2015 - 2019)	141.9 MLD <sup>1</sup>	31.22 MIGD <sup>2</sup>
-----------------------	------------------------	-------------------------

<sup>1</sup>MLD = Million Litres Per Day      <sup>2</sup>MIGD = Million Imperial Gallons Per Day**4. Rainfall September:**

Average (1914 - 2019):	64.7 mm
Actual Rainfall to Date	0.0 mm (0% of monthly average)

**5. Rainfall: Sep 1- Sep 6**

Average (1914 - 2019):	9.6 mm
2019/2020	0.0 mm (0% of average)

**6. Water Conservation Action Required:**

CRD's Stage 1 Water Conservation Bylaw is now in effect through to September 30, 2020.  
Visit [www.crd.bc.ca/water](http://www.crd.bc.ca/water) for scheduling information.

If you require further information, please contact:

Ted Robbins, B.Sc., C.Tech  
General Manager, CRD - Integrated Water Services  
or  
Glenn Harris, Ph D., RPBio  
Senior Manager - Environmental Protection

Capital Regional District Integrated Water Services  
479 Island Highway  
Victoria, BC V9B 1H7  
(250) 474-9600