

## CAPITAL REGIONAL DISTRICT - INTEGRATED WATER SERVICES

### Water Watch for December 12, 2021

#### Water Supply System Summary:

##### 1. Useable Volume in Storage:

Reservoir	December 31 5 Year Ave		December 31/20		December 12/21		% Existing Full Storage
	ML	MIG	ML	MIG	ML	MIG	
Sooke	88,856	19,548	92,727	20,400	92,727	20,400	100.0%
Goldstream	7,505	1,651	9,127	2,008	9,915	2,181	100.0%
Total	96,361	21,199	101,854	22,408	102,642	22,581	100.0%

##### 2. Average Daily Demand:

For the month of December	105.1 MLD	23.11 MIGD
For week ending December 12, 2021	106.1 MLD	23.34 MIGD
Max. day December 2021, to date:	113.7 MLD	25.01 MIGD

##### 3. Average 5 Year Daily Demand for December

Average (2016 - 2020)	97.3 MLD <sup>1</sup>	21.42 MIGD <sup>2</sup>
-----------------------	-----------------------	-------------------------

<sup>1</sup>MLD = Million Litres Per Day      <sup>2</sup>MIGD = Million Imperial Gallons Per Day

##### 4. Rainfall December:

Average (1914 - 2020):	293.9 mm
Actual Rainfall to Date	134.6 mm (46% of monthly average)

##### 5. Rainfall: Sep 1- Dec 12

Average (1914 - 2020):	612.1 mm
2021	1,111.6 mm (182% of average)

##### 6. Water Conservation Action Required:

To avoid possible leaks this spring, now is the time to winterize your sprinkler system.  
Visit our website at [www.crd.bc.ca/water](http://www.crd.bc.ca/water) for more information.

If you require further information, please contact:

Ted Robbins, B.Sc., C.Tech  
General Manager, CRD - Integrated Water Services  
or  
Glenn Harris, Ph D., RPBio  
Senior Manager - Environmental Protection

Capital Regional District Integrated Water Services  
479 Island Highway  
Victoria, BC V9B 1H7  
(250) 474-9600