

CAPITAL REGIONAL DISTRICT - INTEGRATED WATER SERVICES

Water Watch for November 07, 2021

Water Supply System Summary:

1. Useable Volume in Storage:

Reservoir	November 30 5 Year Ave		November 30/20		November 7/21		% Existing Full Storage
	ML	MIG	ML	MIG	ML	MIG	
Sooke	77,240	16,993	80,190	17,642	69,626	15,318	75.1%
Goldstream	7,189	1,582	8,989	1,978	8,404	1,849	84.8%
Total	84,429	18,574	89,179	19,619	78,029	17,166	76.1%

2. Average Daily Demand:

For the month of November	108.0 MLD	23.75 MIGD
For week ending November 07, 2021	108.0 MLD	23.76 MIGD
Max. day November 2021, to date:	115.1 MLD	25.33 MIGD

3. Average 5 Year Daily Demand for November

Average (2016 - 2020)	99.7 MLD ¹	21.93 MIGD ²
-----------------------	-----------------------	-------------------------

¹MLD = Million Litres Per Day ²MIGD = Million Imperial Gallons Per Day

4. Rainfall November:

Average (1914 - 2020):	260.7 mm
Actual Rainfall to Date	100.0 mm (38% of monthly average)

5. Rainfall: Sep 1- Nov 7

Average (1914 - 2020):	290.1 mm
2021	490.4 mm (169% of average)

6. Water Conservation Action Required:

To avoid possible leaks this spring, now is the time to winterize your sprinkler system.
Visit our website at www.crd.bc.ca/water for more information.

If you require further information, please contact:

Ted Robbins, B.Sc., C.Tech
General Manager, CRD - Integrated Water Services
or
Glenn Harris, Ph D., RPBio
Senior Manager - Environmental Protection

Capital Regional District Integrated Water Services
479 Island Highway
Victoria, BC V9B 1H7
(250) 474-9600